



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0306

Cortland City School District

Project Name: Barry School Lead Samples

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 03/02/2017 11:00  
Reported: 03/09/2017 15:24

Analytical Testing Parameters

Client Sample ID: Kitchen Retest Hand Wash Sink B-99  
Lab Sample ID: J7C0306-01  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/02/17  
Collection Time: 06:00

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0580	0.0150	0.000500	mg/L	G	03/06/17 1104	03/08/17 1057	NY

Analytical Testing Parameters

Client Sample ID: Kitchen Retest L.H. Sink B-100  
Lab Sample ID: J7C0306-02  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/02/17  
Collection Time: 06:21

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0472	0.0150	0.000500	mg/L	G	03/06/17 1104	03/08/17 1057	NY

Analytical Testing Parameters

Client Sample ID: Kitchen Retest R.H. Sink B-97  
Lab Sample ID: J7C0306-03  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/02/17  
Collection Time: 06:22

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0189	0.0150	0.000500	mg/L	G	03/06/17 1104	03/08/17 1057	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level  
RL: Reporting Limit  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0306

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale  
Project Manager  
03/09/2017 15:24

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options .

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested										Receiving Info (Lab Use Only)	
Name:	CECSD															Ice:	YES NO
Address:	BARRY SCHOOL															Cooler:	YES NO
Contact:	Nest Helms															Sample Temp:	
Phone:	607 345 4147															Cooler Seal:	YES NO
Project:	Lead															Pickup:	YES NO
Quote ID:																Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 6-7 7-10															Accepted?	YES NO
Release to DOH:	Yes															Container Material	
Email Results:	Yes															Container Size (in Mil)	
Fax Results:	Yes															Preservative	
Sample Information															Comments/Field Data		
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested											
1 KITCHEN Retest	3-2				DO												
HAND WASH SINK	3-2	6:00	SH		G												
2 KITCHEN Retest	3-2	6:20	SH		DO												
L.H. SINK	3-2	6:22	SH		G												
3 KITCHEN Retest	3-2	6:22	SH		DO												
R.H. SINK	3-2	6:22	SH		G												
4																	
5																	
6																	
7																	
8																	

  

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Steven S. Helms	Steven S. Helms	3-2-17	10:47 a.m.
Received:	Nest Helms CSD	Nest Helms	3/8/17	10:50 a.m.
Received:	Hayden Dawson	Hayden Dawson	3/17/17	
Received:				
Received:				