



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C1210

Cortland City School District

Project Name: Barry - Lead Analysis

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 03/22/2017 12:30  
Reported: 03/31/2017 14:50

Analytical Testing Parameters

Client Sample ID: B-97 R.H Kitchen Sink  
Lab Sample ID: J7C1210-01  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/22/17  
Collection Time: 06:12

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00419	0.0150	0.000500	mg/L		03/29/17 1150	03/29/17 1629	NY

Analytical Testing Parameters

Client Sample ID: B-99 Hand Wash Sink  
Lab Sample ID: J7C1210-02  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/22/17  
Collection Time: 06:12

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0153	0.0150	0.000500	mg/L	G	03/29/17 1150	03/29/17 1629	NY

Analytical Testing Parameters

Client Sample ID: B-101 L.H Prep Sink  
Lab Sample ID: J7C1210-03  
Sample Type: Grab

Collected By: SH-Client  
Collection Date: 03/22/17  
Collection Time: 06:12

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0547	0.0150	0.000500	mg/L	G	03/29/17 1150	03/29/17 1629	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level  
RL: Reporting Limit  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 21.2°C

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 3



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C1210

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale  
Project Manager  
03/31/2017 14:50

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options .

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

3824 Buck Drive  
Cortland NY 13046  
Phone: (607) 763-3403 Fax: (607) 763-3415  
NY #10705, EPA #NY00836

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #:	
Name: Cortland City Schools							
Address: Valley View Drive							
Contact: Cortland NY 13047							
Phone: 607-345-4147							
Project: Lead							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes							
Fax Results: Yes							
Sample Information							
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested		
1 B-97 Kitchen Sink	3-22-17	6:12	SH	DW	1		
2 B-99 HAND WASH	3-22-17	6:12	SH	DW	1		
3 B-101 PREP SINK	3-22-17	6:12	SH	DW	1		
4							
5							
6							
7							
8							

  

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Steven S. Hulslander	Steven S. Hulslander	12:15 3-22-17 pm	
Received:	Neal Helms CECs	Neal Helms	12:25 3/22/17 pm	
Received:	Michael Helms - Microbac	Michael Helms	12:30 3/22	
Received:				
Received:				
Received:				



Cortland City School District