



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D1566

Cortland City School District

Project Name: Barry School

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 04/27/2017 10:10
Reported: 05/08/2017 10:07

Analytical Testing Parameters

Client Sample ID: Room 230 DF B-12
Lab Sample ID: J7D1566-01
Sample Type: Grab

Collected By: Client
Collection Date: 04/27/17
Collection Time: 06:22

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0185	0.0150	0.000500	mg/L	G	04/28/17 1010	05/01/17 1130	NY

Analytical Testing Parameters

Client Sample ID: Room 230 DF B-12 - 30 Sec Draw
Lab Sample ID: J7D1566-02
Sample Type: Grab

Collected By: Client
Collection Date: 04/27/17
Collection Time: 06:23

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00552	0.0150	0.000500	mg/L		04/28/17 1010	05/01/17 1130	NY

Analytical Testing Parameters

Client Sample ID: Room 240 CS B-14
Lab Sample ID: J7D1566-03
Sample Type: Grab

Collected By: Client
Collection Date: 04/27/17
Collection Time: 06:25

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00798	0.0150	0.000500	mg/L		05/01/17 1336	05/01/17 1723	NY

Analytical Testing Parameters

Client Sample ID: Room 240 CS B-14 - 30 Sec. Draw
Lab Sample ID: J7D1566-04
Sample Type: Grab

Collected By: Client
Collection Date: 04/27/17
Collection Time: 06:26

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00779	0.0150	0.000500	mg/L		05/01/17 1336	05/01/17 1723	NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D1566

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
SMCL: US EPA Secondary Maximum Contaminant Level
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
05/08/2017 10:07

Go Green: Contact Andrew Canale to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoicing			
Name: <u>Buffy School, CCSO</u>				Billing/Invoicing: _____			
Address: <u>1 Valley View Drive</u>							
Contact: <u>CO Atty, Mr Helm</u>							
Phone: <u>607-245-4147</u>							
Project: <u>Lead</u>							
Quote ID: _____				PO#: _____			
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Date Req.: _____			
Release to DOH: <u>Yes</u>							
Email Results: <u>Yes</u>							
Fax Results: <u>Yes</u>							
Email: <u>shelms@cofhandschools.org</u>							

Sample Information				Matrix			
Description/Location	Date	Time	Initial	Type			
1 Rm 230 DF B-12	4-27-17	6:22	SH	DW			
2 Rm 230 3000e draw-DF B-12	4-27-17	6:23	SA	DW			
3 Rm 240 C.S B-14	4-27-17	6:25	SH	DW			
4 Rm 240 C.S B-14 30 sec. draw	4-27-17	6:26	SH	DW			
5							
6							
7							
8							

Print Name and Company		Signature	Date/Time
Sampled: <u>Steven S. Helms</u>	<u>CCSO</u>	<u>Steven S. Helms</u>	<u>4-27-17 6:30</u>
Received: <u>Neil Helms</u>	<u>CCSO</u>	<u>Neil Helms</u>	<u>4-27-17 4:50 am</u>
Received: <u>Don Beacham</u>		<u>Don Beacham</u>	<u>4-27-17 10:10</u>
Received: _____			
Received: _____			
Received: _____			

Receiving Info (Lab Use Only)	
Ice: <u>YES</u> <u>NO</u>	
Cooler: <u>YES</u> <u>NO</u>	
Sample Temp: _____	
Cooler Seal: <u>YES</u> <u>NO</u>	
Pickup: <u>YES</u> <u>NO</u>	
Dropoff: <u>C</u> <u>W</u>	
Accepted? <u>YES</u> <u>NO</u>	
Container Material	
Container Size (in Mi)	
Preservative	
Comments/Field Data	