



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7E1143

Cortland City School District

Project Name: Lead Analysis

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 05/16/2017 10:00
Reported: 05/18/2017 10:25

Analytical Testing Parameters

Client Sample ID: B-12 Room 230 DF (Restest)
Lab Sample ID: J7E1143-01
Sample Type: Grab

Collected By: SH-Client
Collection Date: 05/16/17
Collection Time: 06:12

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0319	0.0150	0.000500	mg/L	G	05/16/17 1243	05/16/17 1431	NY

Analytical Testing Parameters

Client Sample ID: B-89 Room 190 BS (Restest)
Lab Sample ID: J7E1143-02
Sample Type: Grab

Collected By: SH-Client
Collection Date: 05/16/17
Collection Time: 06:30

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.146	0.0150	0.00500	mg/L	G	05/16/17 1243	05/16/17 1431	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7E1143

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
05/18/2017 10:25

Go Green: Contact Andrew Canale to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

