



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7E1444

Cortland City School District

Project Name: Barry Elementary

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 05/19/2017 10:06
Reported: 05/31/2017 14:26

Analytical Testing Parameters

Client Sample ID: B-12 Room 230 DF Retest
Lab Sample ID: J7E1444-01
Sample Type: Grab

Collected By: NH-Client
Collection Date: 05/16/17
Collection Time: 07:40

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0230	0.0150	0.000500	mg/L	G	05/25/17 1452	05/26/17 1352	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
05/31/2017 14:26

Go Green: Contact Andrew Canale to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Christine Pechacek, Laboratory Director at christine.pechacek@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #:	
Name: <u>Buffy Elementary</u>							
Address: <u>Valley View Drive</u>							
City: <u>Cortland, NY 13805</u>							
Contact: <u>Veri/Helm</u>							
Phone: <u>607-345-4147</u>							
Project: <u>Lead</u>							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOL: <u>Yes</u>							
Email Results: <u>Veri/Helm@CortlandSchools.org</u>							
Fax Results: <u>Yes</u>							
Sample Information							
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	
1 B-10 Room 230 DPE Refer	5/16/17	2:45	TH	BW	G	1	
2							
3							
4							
5							
6							
7							
8							

Receiving Info (Lab Use Only)		Comments	
Ice:	YES NO		
Cooler:	YES NO		
Sample Temp:			
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES NO		
Container Material			
Container Size (in ml)			
Preservative			
Comments/Field Data			
p2a)			
250ml			
p			
H1003			
1			

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Veri/Helm Cortland Schools	Veri/Helm		5/16/17 2:45pm	
Raymond Dawson	Raymond Dawson		5/17/17 10:06	
Received:				
Received:				
Received:				
Received:				
Received:				

