



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7F0297

Cortland City School District

Project Name: Barry Elementary

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 06/02/2017 11:24  
Reported: 06/08/2017 08:04

Analytical Testing Parameters

Client Sample ID: B-12 Room 230 DF (Flex line)  
Lab Sample ID: J7F0297-01  
Sample Type: Grab

Collected By: Client  
Collection Date: 06/02/17  
Collection Time: 06:36

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.115	0.0150	0.000500	mg/L	GE2	06/06/17 1013	06/06/17 1120	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level  
E2: Estimated result due to target analyte exceeding calibration range.  
RL: Reporting Limit  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 23.1°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale  
Project Manager  
06/08/2017 08:04

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Christine Pechacek, Laboratory Director at [christine.pechacek@microbac.com](mailto:christine.pechacek@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | [www.microbac.com](http://www.microbac.com)

Page 1 of 2

Microbac Laboratories, Inc.  
**CHAIN OF CUSTODY**

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:	
Name: <u>Bailey Elementary</u>					
Address: <u>1 Valley View Drive</u>					
City/State/Zip: <u>Cortland, NY 13045</u>					
Contact: <u>Neg Helms</u>					
Phone: <u>607 345 4147</u>					
Project: <u>Lead</u>				PO#:	
Quote ID:				Date Req.:	
Rush TAT Bus. Days: <2 2-5 5-7 7-10					
Release to DOH: Yes					
Email Results: Yes				h/helms@CortlandSchools.net	
Fax Results: Yes					
Sample Information					
Description/Location	Date	Time	Initial	Matrix	Type
1 B-12 Room 230 DF Flex line	6/2/17	6:36 am	NH		DW
2					
3					
4					
5					
6					
7					
8					

1

23.1°C

YES NO

YES NO

YES NO

YES NO

C W

YES NO

Container Material

Container Size (in MI)

Preservative

Accepted? YES NO

Comments/Field Data

J7F0297

Print Name and Company	Signature	Date/Time	Comments
Sampled: <u>Neg Helms Cortland Schools</u>	<u>Neg Helms</u>	<u>6/2/17 6:40</u>	***PLACE ALL SAMPLES IN BAGS WITH ICE.***
Received: <u>Jennifer Walker MIT Junior Walker</u>	<u>Jennifer Walker</u>	<u>6/2/17 11:24</u>	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.