



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J711765

Cortland City School District

Project Name: Lead Analysis

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/22/2017 10:46
Reported: 10/06/2017 08:52

Analytical Testing Parameters

Client Sample ID: B-10 B.S. Room 230 Bathroom retest
Lab Sample ID: J711765-01
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:10

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0125	0.0150	0.000500	mg/L		09/24/17 1449	09/24/17 1632	NY

Analytical Testing Parameters

Client Sample ID: B-12 Room 230 Drinking Fountain Retest
Lab Sample ID: J711765-02
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:12

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00983	0.0150	0.000500	mg/L		09/24/17 1449	09/24/17 1632	NY

Analytical Testing Parameters

Client Sample ID: B-15 RM 245 Drinking Fountain Retest
Lab Sample ID: J711765-03
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:15

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0425	0.0150	0.000500	mg/L	G	09/24/17 1449	09/24/17 1632	NY

Analytical Testing Parameters

Client Sample ID: B-46 Rm 350 Drinking Fountain Retest
Lab Sample ID: J711765-04
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:25

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0188	0.0150	0.000500	mg/L	G	09/26/17 1212	10/04/17 1201	NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J711765

Analytical Testing Parameters

Client Sample ID: B-79 Rm 150 Drinking Fountain Retest
Lab Sample ID: J711765-05
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:21

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0370	0.0150	0.000500	mg/L	G	09/24/17 1449	09/24/17 1632	NY

Analytical Testing Parameters

Client Sample ID: B-89 Rm 190 Bathroom Sink Retest
Lab Sample ID: J711765-06
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/22/17
Collection Time: 06:19

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0351	0.0150	0.000500	mg/L	G	09/26/17 1212	10/04/17 1201	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 22.6°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J711765

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Alayna Dawson
Administrative Assistant
10/06/2017 08:52

Go Green: Contact Alayna Dawson to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Alayna Dawson, Project Manager at alayna.dawson@microbac.com. You may also contact Christine Pechacek, Laboratory Director at christine.pechacek@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Address:	Contact:	Phone:	Project:	Quote ID:	Rush TAT Bus. Days:	Release to DOH:
BARRY Elementary	Valley View Drive	Cortland, NY 13045	607-345-4147	legd		<2 2-5 5-7 7-10	Yes
Email Results: <input checked="" type="checkbox"/> Yes		Fax Results: <input checked="" type="checkbox"/> Yes		PO#:		Date Req.:	
Sample Information		Matrix		Number of Containers for Analysis Requested		Preservative	
Description/Location	Date	Time	Initial	Type	Comments	Container Material	Container Size (in MI)
1 B-10 Rm 230 Bathroom Refest	9/22/17	6:10	27K	DW			
2 B-12 Rm 230 Drinking Fountain Refest	9/22/17	6:12	27K	DW			
3 B-15 Rm 240 Drinking Fountain Refest	9/22/17	6:15	27K	DW			
4 B-21 Rm 200 Bathroom Refest	9/22/17	6:20	27K	DW			
5 B-46 Rm 350 Drinking Fountain Refest	9/22/17	6:25	27K	DW			
6 B-79 Rm 150 Drinking Fountain Refest	9/22/17	6:21	27K	DW			
7 B-89 Rm 190 Bathroom Sink	9/22/17	6:19	27K	DW			
8							
Print Name and Company		Signature		Date/Time		Comments	
Sampled: <i>Wegman's Cortland School</i>		<i>David Nelson</i>		9/22/17 6:10am		***PLACE ALL SAMPLES IN BAGS WITH ICE.***	
Received: <i>David Nelson</i>		<i>David Nelson</i>		9/22/17 10:40		HN03 Not Preserved	
Received:						HN03 added 9/22/17 1:345	
Received:							
Received:							
Received:							