



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7I2039

Cortland City School District

Project Name: Barry Elementary

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/27/2017 10:27
Reported: 10/05/2017 09:54

Analytical Testing Parameters

Client Sample ID: B-21 Rm 260 Bathroom Sink
Lab Sample ID: J7I2039-01
Sample Type: Grab

Collected By: NH-Client
Collection Date: 09/27/17
Collection Time: 06:25

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0104	0.0150	0.000500	mg/L		09/28/17 1136	09/29/17 2000	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 26.7°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Alayna Dawson
Administrative Assistant
10/05/2017 09:54

Go Green: Contact Alayna Dawson to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Alayna Dawson, Project Manager at alayna.dawson@microbac.com. You may also contact Christine Pechacek, Laboratory Director at christine.pechacek@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

CHAIN OF CUSTODY

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Barry Elementary					Ice:	YES NO
Address:	1 Valleyview Drive					Cooler:	YES NO
Contact:	Cortland NY 13045					Sample Temp:	26.2
Phone:	607-345-4147					Cooler Seal:	YES NO
Project:	legd					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10					Accepted?	YES NO
Release to DOH:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information				Comments/Field			
Description/Location	Date	Time	Initial	Number of Containers for Analysis Requested			
1 B-21 Rm 260 Bath room sink	9/29/07	6:20 AM	DK	1			
2							
3							
4							
5							
6							
7							
8							
Print Name and Company				Signature		Date/Time	
Sampled: Ver Helms Cortland schools				Neal Helms		9/29/07 10:27	
Received: Dorothy Nashaw				Dorothy Nashaw		9-27-17 10:27	
Received:							
Received:							
Received:							
Received:							
Received:							
Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.				***PLACE ALL SAMPLES IN BAGS WITH ICE.***			
By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.							

