



Cortland Enlarged City School District Lead Testing

Building	# of Samples Submitted	# of Results Received	# of Samples Above 15 ppb.	Location	Remediation
Barry Elementary	95	95	21	Room 200 Bathroom sink Room 230 Bathroom sink Room 230 Drinking fountain Room 240 Bathroom sink Room 240 classroom sink Room 240 drinking fountain Room 250 Bathroom sink Room 260 Bathroom sink Room 270 Bathroom sink Hallway drinking fountain Room 110 Bathroom sink Room 120 drinking fountain Room 140 drinking fountain Room 150 drinking fountain Room 180 Bathroom sink Room 180 Classroom sink Room 190 Bathroom sink Room 190 Classroom sink Room 220 drinking fountain Room 230 drinking fountain Room 350 drinking fountain	Replace and retest Replace and retest Replace and retest Replace and retest Repair and replace Repair and replace Replace and repair Replace and retest Replace and retest Replace and retest Replace and retest Removed Removed Replace and retest Replace and retest Replace and retest Replace and retest Remove Remove Replace and retest



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Cortland City School District

Project Name: Barry Elementary School

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/21/2016
Reported: 10/25/2016

Analytical Testing Parameters

Client Sample ID: B-1 Bathroom Sink
Sample Matrix: Drinking Water
Lab Sample ID: J6I1105-01

Collected By: SH-Client
Collection Date: 09/21/2016 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.027	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1520

Client Sample ID: B-2 Drinking Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J6I1105-02

Collected By: SH-Client
Collection Date: 09/21/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0088	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1520

Client Sample ID: B-3 Classroom Sink
Sample Matrix: Drinking Water
Lab Sample ID: J6I1105-03

Collected By: SH-Client
Collection Date: 09/21/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0052	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1521

Client Sample ID: B-4 Bathroom Sink
Sample Matrix: Drinking Water
Lab Sample ID: J6I1105-04

Collected By: SH-Client
Collection Date: 09/21/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1522

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Client Sample ID: B-5 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-05

Collected By: SH-Client

Collection Date: 09/21/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0085	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1522

Client Sample ID: B-6 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-06

Collected By: SH-Client

Collection Date: 09/21/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0054	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1524

Client Sample ID: B-7 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-07

Collected By: SH-Client

Collection Date: 09/21/2016 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0084	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1526

Client Sample ID: B-8 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-08

Collected By: SH-Client

Collection Date: 09/21/2016 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0069	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1527



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Client Sample ID: B-9 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-09

Collected By: SH-Client

Collection Date: 09/21/2016 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0045	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1528

Client Sample ID: B-10 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-10

Collected By: SH-Client

Collection Date: 09/21/2016 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1528

Client Sample ID: B-11 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-11

Collected By: SH-Client

Collection Date: 09/21/2016 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0030	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1529

Client Sample ID: B-12 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-12

Collected By: SH-Client

Collection Date: 09/21/2016 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.034	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1529



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611105

Client Sample ID: B-13 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611105-13

Collected By: SH-Client

Collection Date: 09/21/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1530

Client Sample ID: B-14 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611105-14

Collected By: SH-Client

Collection Date: 09/21/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.17	0.015	0.0010	mg/L	E	10/05/16 0800	10/12/16 1531

Client Sample ID: B-15 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J611105-15

Collected By: SH-Client

Collection Date: 09/21/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.024	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1531

Client Sample ID: B-16 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611105-16

Collected By: SH-Client

Collection Date: 09/21/2016

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.046	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1535



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Client Sample ID: B-17 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-17

Collected By: SH-Client

Collection Date: 09/21/2016 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0042	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1535

Client Sample ID: B-18 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-18

Collected By: SH-Client

Collection Date: 09/21/2016 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0066	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1536

Client Sample ID: B-19 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-19

Collected By: SH-Client

Collection Date: 09/21/2016 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0056	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1537

Client Sample ID: B-20 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-20

Collected By: SH-Client

Collection Date: 09/21/2016 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0087	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1537



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Client Sample ID: B-21 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-21

Collected By: SH-Client

Collection Date: 09/21/2016 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.020	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1538

Client Sample ID: B-22 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-22

Collected By: SH-Client

Collection Date: 09/21/2016 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.048	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1539

Client Sample ID: B-23 Classroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-23

Collected By: SH-Client

Collection Date: 09/21/2016 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0066	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1539

Client Sample ID: B-24 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1105-24

Collected By: SH-Client

Collection Date: 09/21/2016 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.014	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1540



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611105

Client Sample ID: B-25 Next to Room 265 Staff Bathroom

Sample Matrix: Drinking Water

Lab Sample ID: J611105-25RE1

Collected By: SH-Client

Collection Date: 09/21/2016 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0052	0.015	0.0010	mg/L		10/05/16 0800	10/13/16 1247

Client Sample ID: B-26 Kids Bathroom Next to Room 264

Sample Matrix: Drinking Water

Lab Sample ID: J611105-26RE1

Collected By: SH-Client

Collection Date: 09/21/2016 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0051	0.015	0.0010	mg/L		10/05/16 0800	10/13/16 1249

Client Sample ID: B-27 Hallway Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J611105-27RE1

Collected By: SH-Client

Collection Date: 09/21/2016 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.022	0.015	0.0010	mg/L		10/05/16 0800	10/13/16 1250

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level

E: Estimated result

MDL: Minimum Detection Limit

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

New York State Department of Health

PA DEP ID: 68-04863

Pennsylvania Department of Environmental Protection



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1105

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Michael Fifield
Division Manager
michael.fifield@microbac.com
10/25/2016 12:28

3021 Buok Drive
Cortland NY 13045
Phone: (607) 763-3403 Fax: (607) 763-3415
NY #10766, EPA #NYC00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland E.S.D.							Ice:	YES NO
Address:	Barry Elem							Cooler:	YES NO
Contact:								Sample Temp:	
Phone:								Cooler Seal:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days: <2 2-5 5-7 7-10								Accepted?	YES NO
Release to DOH: <input checked="" type="checkbox"/>								Container Material	
Email Results: <input checked="" type="checkbox"/> Rmartin@cortlandschools.org								Container Size (in Mi)	
Fax Results: <input checked="" type="checkbox"/> Kweldby@cortlandschools.org								Preservative	
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data	
Description/Location	Date	Time	Initial	Matrix Type					
1 B-01/BATH-SINK	9-21	6:10	SH	SW					
2 B-02/DRINK FOUNT.	9-21	6:13	SH	Rob					
3 B-03/CLASS SINK	9-21	6:15	SH						
4 B-04/BATH SINK	9-21	6:19	SH						
5 B-05/DRINK FOUNT	9-21	6:19	SH						
6 B-06/CLASS SINK	9-21	6:19	SH						
7 B-07/BATH SINK	9-21	6:25	SH						
8 B-08/DRINK FOUNT	9-21	6:25	SH	V					
Print Name and Company				Signature	Date/Time		Comments		
Sampled: Steven S. Hudgins/DARY				Steven S. Hudgins	9-21-16				
Received: BOG MARTIN / C.E.S.D				BLM	9/21/16 12:20				
Received: Jennifer Walker mca				Jennifer Walker	9/21/16 14:23				
Received:									
Received:									
Received:									



J611105

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on Ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: <u>CORTLAND CCSD</u>								Ice: YES NO	
Address: <u>BARRY ELEM.</u>								Cooler: YES NO	
Contact:								Sample Temp:	
Phone:								Cooler Seal: YES NO	
Project:								Pickup: YES NO	
Quote ID:								Dropoff: C W	
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:				Accepted? YES NO	
Release to POH: Yes								Container Material	
Email Results: Yes <u>RMATING@CORTLANDSCHOOLS.ORG</u>								Container Size (in M)	
Fax Results: Yes <u>KUPLADBY@CORTLANDSCHOOLS.ORG</u>								Preservative	
Sample Information				Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type				
1 B-09/CLASS SINK	9-21	6:28	SH						
2 B-10/BATH SINK	9-21	6:33	SH						
3 B-11/CLASS SINK	9-21	6:33	SH						
4 B-12/DRINK FOUNT.	9-21	6:33	SH						
5 B-13/BATH SINK	9-21	6:47	SH						
6 B-14/CLASS SINK	9-21	6:47	SH						
7 B-15/DRINK FOUNT.	9-21	6:47	SH						
8 B-16/BATH SINK									

Print Name and Company		Signature	Date/Time	Comments
Sample: <u>STEVEN S. HULSTANDER/BADAY</u>		<u>Steven S. Hulstander</u>	<u>9-21-16</u>	
Received: <u>BOB MARTIN/CCSD</u>		<u>Bob Martin</u>	<u>9/21/16 2:20</u>	
Received: <u>Jennifer Walker Mgr.</u>		<u>Jennifer Walker</u>	<u>9/21/16 1403</u>	
Received:				
Received:				
Received:				

3021 Buck Drive
Cortland NY 13846
Phone: (607) 763-3403 Fax: (607) 763-3416
NY #10795, EPA #NY00085

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: <u>BARRY CORTLAND CCSD</u>								Ice: YES NO	
Address: <u>BARRY GLEM.</u>								Cooler: YES NO	
Contact:								Sample Temp:	
Phone:								Cooler Seal: YES NO	
Project:								Pickup: YES NO	
Quote ID:								Dropoff: C W	
Rush TAT Bus. Days: <2 2-6 6-7 7-10				Date Req.:				Accepted? YES NO	
Release to DOH: <u>Yes</u>								Container Material	
Email Results: <u>Yes</u> <u>RMARTIN@CORTLANDSCHS.HOUS.ORG</u>								Container Size (in Mi)	
Fax Results: <u>Yes</u> <u>KWADBY@CORTLANDSCHS.HOUS.ORG</u>								Preservative	
Sample Information				Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location		Date	Time	Initial	Type				
1	B-17/CLASS SINK	9-21-16	7:00	SH					
2	B-18/DRINK FOUNT	9-21-16	7:00	SH					
3	B-19/DRINK FOUNT	9-21-16	7:08	SH					
4	B-20/CLASS SINK	9-21-16	7:08	SH					
5	B-21/BATH SINK	9-21-16	7:08	SH					
6	B-22/BATH SINK	9-21-16	7:15	SH					
7	B-23/CLASS SINK	9-21-16	7:15	SH					
8	B-24/DRINK FOUNT	9-21-16	7:15	SH					
Print Name and Company					Signature	Date/Time	Comments		
Sampled: <u>Steven S. Hulsander/BARRY</u>					<u>Steven S. Hulsander</u>	<u>9-21-16</u>			
Received: <u>BOB MARTIN/CCSD</u>					<u>BOB MARTIN</u>	<u>9/21/16 6:20</u>			
Received: <u>Jennifer Waller MTS</u>					<u>Jennifer Waller</u>	<u>9/21/16 1:43</u>			
Received:									
Received:									
Received:									

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:				Analyte Requested				Receiving Info (Lab Use Only)			
Name: CORLAND CCSD				Address: BARRY ELEM.				Contact:				Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			
Phone:				Project:				Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				Sample Temp: 26.1			
Quote ID:				PO#:				Cooler Seal: YES NO				Pickup: YES NO			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:				Dropoff: G / W				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			
Email Results: Yes RMARTIN@CORLANDSCHOOLS.ORG				Fax Results: Yes KVALDBY@CORLANDSCHOOLS.ORG				Container Material				Container Size (in Ml)			
Sample Information				Matrix				Preservative				Commercial/Field Data			
Description/Location		Date		Time		Initial		Type		Number of Containers for Analysis Requested		Comments			
1 B-25/STAFF BATH.		9-21-16		7:21		SH		SH							
2 B-26/STAFF BATH		9-21-16		7:21		SH		SH							
3 B-27/DRINK FOUNTAIN		9-21-16		7:21		SH		SH							
4															
5															
6															
7															
8															
9															
10															
Sampled: STEVEN S. HULSLANDER/BARRY STONE S. HULSLANDER				Signature				Date/Time				Comments			
Received: BOB MARTIN / CRESO				9-21-16											
Received: BRUNNER WALKER MLD				9-21-16											
Received:				9-21-16											
Received:				9-21-16											
Received:				9-21-16											



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Cortland City School District

Project Name: Barry Elementary

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/23/2016
Reported: 10/25/2016

Analytical Testing Parameters

Client Sample ID: B-28 D.F. across from Library
Sample Matrix: Drinking Water
Lab Sample ID: J6I1109-01

Collected By: SH-Client
Collection Date: 09/23/2016 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0041	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2043

Client Sample ID: B-29 B.S. Across from Library
Sample Matrix: Drinking Water
Lab Sample ID: J6I1109-02

Collected By: SH-Client
Collection Date: 09/23/2016 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2043

Client Sample ID: B-30 D.F. Room 410
Sample Matrix: Drinking Water
Lab Sample ID: J6I1109-03

Collected By: SH-Client
Collection Date: 09/23/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0029	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2044

Client Sample ID: B-31 C.S Room 410
Sample Matrix: Drinking Water
Lab Sample ID: J6I1109-04

Collected By: SH-Client
Collection Date: 09/23/2016 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0064	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2046

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 12



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Client Sample ID: B-32 B.S. Room 410

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-05

Collected By: SH-Client

Collection Date: 09/23/2016 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0040	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2047

Client Sample ID: B-33 B.S. Room 400

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-06

Collected By: SH-Client

Collection Date: 09/23/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0036	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2047

Client Sample ID: B-34 D.F. Room 400

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-07

Collected By: SH-Client

Collection Date: 09/23/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0014	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2048

Client Sample ID: B-35 C.S. Room 400

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-08

Collected By: SH-Client

Collection Date: 09/23/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0013	0.015	0.0010	mg/L		10/10/16 0806	10/18/16 2049



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Client Sample ID: B-36 B.S. Room 430

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-09

Collected By: SH-Client

Collection Date: 09/23/2016 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0027	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1741

Client Sample ID: B-37 C.S. Room 430

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-10

Collected By: SH-Client

Collection Date: 09/23/2016 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0017	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1741

Client Sample ID: B-38 D.F. Room 430

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-11

Collected By: SH-Client

Collection Date: 09/23/2016 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0014	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1742

Client Sample ID: B-39 B.S. Room 420

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-12

Collected By: SH-Client

Collection Date: 09/23/2016 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0048	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1743



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Client Sample ID: B-40 C.S. Room 420

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-13

Collected By: SH-Client

Collection Date: 09/23/2016 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0012	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1743

Client Sample ID: B-41 D.F. Room 420

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-14

Collected By: SH-Client

Collection Date: 09/23/2016 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1744

Client Sample ID: B-42 D.F. Room 330

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-15

Collected By: SH-Client

Collection Date: 09/23/2016 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0051	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1745

Client Sample ID: B-43 C.S. Room 330

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-16

Collected By: SH-Client

Collection Date: 09/23/2016 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0045	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1745



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611109

Client Sample ID: B-44 D.F. Room 340

Sample Matrix: Drinking Water

Lab Sample ID: J611109-17

Collected By: SH-Client

Collection Date: 09/23/2016 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0096	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1746

Client Sample ID: B-45 C.S. Room 340

Sample Matrix: Drinking Water

Lab Sample ID: J611109-18

Collected By: SH-Client

Collection Date: 09/23/2016 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0054	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1747

Client Sample ID: B-46 D.F. Room 350

Sample Matrix: Drinking Water

Lab Sample ID: J611109-19

Collected By: SH-Client

Collection Date: 09/23/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1749

Client Sample ID: B-47 C.S. Room 350

Sample Matrix: Drinking Water

Lab Sample ID: J611109-20

Collected By: SH-Client

Collection Date: 09/23/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0090	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1749



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Client Sample ID: B-48 D.F. Room 370

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-21

Collected By: SH-Client

Collection Date: 09/23/2016 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.014	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1750

Client Sample ID: B-49 C.S. Room 370

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-22

Collected By: SH-Client

Collection Date: 09/23/2016 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0045	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1751

Client Sample ID: B-50 C.S. Room 360

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-23

Collected By: SH-Client

Collection Date: 09/23/2016 6:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0062	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1751

Client Sample ID: B-51 D.F. Room 360

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-24

Collected By: SH-Client

Collection Date: 09/23/2016 6:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0079	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1752



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611109

Client Sample ID: B-52 D. F. Room 380

Sample Matrix: Drinking Water

Lab Sample ID: J611109-25

Collected By: SH-Client

Collection Date: 09/23/2016 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0082	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1752

Client Sample ID: B-53 C.S. Room 380

Sample Matrix: Drinking Water

Lab Sample ID: J611109-26

Collected By: SH-Client

Collection Date: 09/23/2016 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1753

Client Sample ID: B-54 B.S. Left Cluster Boys Bathroom

Sample Matrix: Drinking Water

Lab Sample ID: J611109-27

Collected By: SH-Client

Collection Date: 09/23/2016 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1754

Client Sample ID: B-55 B.S. Right Cluster Boys Bathroom

Sample Matrix: Drinking Water

Lab Sample ID: J611109-28

Collected By: SH-Client

Collection Date: 09/23/2016 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0039	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1754



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1109

Client Sample ID: B-56 Girls Cluster Bthroom Left

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-29

Collected By: SH-Client

Collection Date: 09/23/2016 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0026	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1756

Client Sample ID: B-57 Girls Cluster Bathroom Right

Sample Matrix: Drinking Water

Lab Sample ID: J6I1109-30

Collected By: SH-Client

Collection Date: 09/23/2016 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0027	0.015	0.0010	mg/L		10/10/16 0806	10/14/16 1757

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level

MDL: Minimum Detection Limit

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No: 10795

New York State Department of Health

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

New York State Department of Health

PA DEP ID: 68-04863

Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Michael Fifield
Division Manager
michael.fifield@microbac.com
10/25/2016 12:28

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 8 of 12

3021 Buck Drive
Corland NY 13046
Phone: (607) 768-3403 Fax: (607) 768-3415
NY #10706, EPA #NY00096

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information			Billing/Invoice:	
Name:	CORTLAND CCSD			
Address:	BARRY ELEM.			
Contact:				
Phone:				
Project:				
Quote ID:	PO#:			
Rush TAT Bus. Days:	<2	2-5	6-7	7-10
Release to DOH?	Yes			
Email Results:	Yes			
Fax Results:	Yes			
Email Results: Yes				
Fax Results: Yes				
Release to DOH? Yes				
Email Results: Yes				
Fax Results: Yes				
Release to DOH? Yes				
Sample Information				
Description/Location	Date	Time	Initial	Matrix Type
1 B-28 / D.F. ACROSS FROM LIB.	9-23-16	6:09	SH	
2 B-29 / FROM LIB.	9-23-16	6:11	SH	
3 B-30 / D.F. RM. 410	9-23-16	6:13	SH	
4 B-31 / C.S. RM. 410	9-23-16	6:16	SH	
5 B-32 / B.S. RM. 410	9-23-16	6:16	SH	
6 B-33 / B.S. 400	9-23-16	6:19	SH	
7 B-34 / D.F. RM. 400	9-23-16	6:19	SH	
8 B-35 / C.S. RM. 400	9-23-16	6:19	SH	
Number of Containers for Analysis Requested				
Comments				
Receiving Info (Lab Use Only)				
Ice:	YES NO			
Cooler:	YES NO			
Sample Temp:	26.9			
Cooler Seal:	YES NO			
Pickup:	YES NO			
Dropoff:	C W			
Accepted?	YES NO			
Container Material				
Container Size (in MI)				
Preservative				
Commercial Field Data				
Signature				
Date/Time				
Comments				
Sampled: Steven Hulsander / BARRY				
Received: BOB MARTIN CCSD				
Received: Aileen Dawson				
Received:				
Received:				
Received:				



J611109

3021 Buck Drive
Corland NY 13046
Phone: (607) 765-3408 Fax: (607) 765-3416
NY #10706, EPA #NY100936

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: CORLAND CCSD						Ice: YES NO		Cooler: YES NO	
Address: BARRY ELEM						Sample Temp: 26.9		Cooler Seal: YES NO	
Contact:						Pickup: YES NO		Dropoff: C W	
Phone:						Accepted? YES NO			
Project:						Container Material		Container Size (in MI)	
Quote ID:						Preservative		Comments/Field Data	
Rush TAT Bie. Days: <2 2-5 5-7 7-10				Date Req:		Number of Containers for Analysis Requested			
Release to DOH: Yes									
Email Results: Yes				B-MARTIN@CORLANDSCHOOLS.ORG					
Fax Results: Yes				K.WALDBY@CORLANDSCHOOLS.ORG					
Sample Information				Matrix					
Description/Location		Date	Time	Initial	Type				
1 B-36/Rm 430	C.S	9-23-16	6:32	SH					
2 B-37/Rm 430	D.F.	9-23-16	6:32	SH					
3 B-38/Rm 430	B-S	9-23-16	6:32	SH					
4 B-39/Rm 420	C.S	9-23-16	6:37	SH					
5 B-40/Rm 420	D.F.	9-23-16	6:37	SH					
6 B-41/Rm 420	D.F.	9-23-16	6:37	SH					
7 B-42/Rm 330	C.S	9-23-16	6:42	SH					
8 B-43/Rm 330		9-23-16	6:42	SH					

Print Name and Company		Signature	Date/Time	Comments
Sampled: Steven S. Hulslander/BARRY		Steven S. Hulslander	9-23-16 10:37	
Received: BOB MARTIN CCSD		Bl-Martin	9/23/16 10:37	
Recalled: Alayna Dawson		Alayna Dawson	9/23/16 15:00	
Received:				
Received:				
Received:				

3021 Buck Drive
Cortland NY 13046
Phone: (607) 768-3409 Fax: (607) 768-3416
NY #10706, EPA #NY100935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:	
Name: <u>CORTLAND CCSD</u>					
Address: <u>BARRY ELEM</u>					
Contact:					
Phone:					
Project:					
Quote ID:				PO#:	
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req: _____	
Release to DOH: <u>Yes</u>					
Email Results: <u>Yes</u> <u>RMARTIN@CORTLANDSCHS.HOUS.ORG</u>					
Fax Results: <u>Yes</u> <u>KVALDBY@CORTLANDSCHS.HOUS.ORG</u>					
Sample Information				Analyte Requested	
Description/Location	Date	Time	Initial	Matrix	Type
1 B-44 / D.F. RM 340	9-23-16	6:49	SH		
2 B-45 / CS RM 340	9-23-16	6:49	SH		
3 B-46 / D.F. RM 350	9-23-16	6:47	SH		
4 B-47 / CS RM 350	9-23-16	6:47	SH		
5 B-48 / D.F. Room 370	9-23-16	6:50	SH		
6 B-49 / CS RM 370	9-23-16	6:50	SH		
7 B-50 / CS RM 360	9-23-16	6:54	SA		
8 B-51 / D.F. RM 360	9-23-16	6:54	SH		
Print Name and Company				Signature	
Sampled: <u>Stewart S. Hulstader / BARRY</u>				<u>Stewart S. Hulstader</u>	
Received: <u>B.B. Martin CCSD</u>				<u>B.B. Martin</u>	
Received: <u>Flaynartawson</u>				<u>Flaynartawson</u>	
Received:					
Received:					
Received:					
Date/Time				Comments	
9-23-16 - 10:39					
9-23-16 - 10:37					
9-23-16 - 1:50					

Receiving Info (Lab Use Only)	
Ice: <u>YES</u> <u>NO</u>	
Cooler: <u>YES</u> <u>NO</u>	
Sample Temp: <u>26.9</u>	
Cooler Seal: <u>YES</u> <u>NO</u>	
Pickup: <u>YES</u> <u>NO</u>	
Dropoff: <u>C</u> <u>W</u>	
Accepted? <u>YES</u> <u>NO</u>	
Container Material	
Container Size (in ml)	
Preservative	
Comments/Field Data	

3021 Buck Drive
Cortland NY 13048
Phone: (607) 765-3403 Fax: (607) 765-3416
NY #10795, EPA #NY000935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:			
Name: CORTLAND CCSO							
Address: BARRY ELEM							
Contact:							
Phone:							
Project:							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes RMARTIN@CORTLANDSCHSOLS.ORG							
Fax Results: Yes KWHOBLY@CORTLANDSCHSOLS.ORG							
Sample Information				Analyte Requested			
Description/Location	Date	Time	Initial	Number of Containers for Analyte Requested		Comments	
1 B-52 / DF	9-23-16	6:58	SH				
2 B-53 RM 380	9-23-16	6:58	SH				
3 B-54 B5 LEFT	9-23-16	7:02	SH				
4 B-55 B5 RIGHT	9-23-16	7:02	SH				
5 B-56 B5 BOTTOM	9-23-16	7:02	SH				
6 B-57 B5 BOTTOM - Right	9-23-16	7:06	SH				
7							
8							
Print Name and Company				Signature			
Sampled: Steven Hulslander				Steven Hulslander			
Received: Bob Martin				Bob Martin			
Received: Hayma Dawson				Hayma Dawson			
Received:							
Received:							
Received:							

Receiving Info (Lab Use Only)	
Ice:	YES NO
Container:	YES NO
Sample Temp:	26.9
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container Size (in Mi)	
Preservative	
Comments/Field Data	



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Cortland City School District

Project Name: Barry Elementary

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/26/2016
Reported: 10/25/2016

Case Narrative

The Matrix Spike Duplicate performed on the following sample failed the precision criteria for lead. The accuracy criteria were met by both the Matrix Spike and Matrix Spike Duplicate. This data is indicative of a bias related to sample matrix.

Laboratory ID Sample Name
16I1854-05 J6I1230-05 (B-62 CS Left Rm 100)

Analytical Testing Parameters

Client Sample ID: B-58 Cafeteria Sink
Sample Matrix: Drinking Water
Lab Sample ID: J6I1230-01
Collected By: SH-Client
Collection Date: 09/24/2016 8:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0058	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1408

Client Sample ID: B-59 DF Lobby Gym
Sample Matrix: Drinking Water
Lab Sample ID: J6I1230-02
Collected By: SH-Client
Collection Date: 09/24/2016 8:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0027	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1408

Client Sample ID: B-60 BS Rm 100
Sample Matrix: Drinking Water
Lab Sample ID: J6I1230-03
Collected By: SH-Client
Collection Date: 09/24/2016 8:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0087	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1409

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 16



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-61 CS Right Rm 100

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-04

Collected By: SH-Client

Collection Date: 09/24/2016 8:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0042	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1410

Client Sample ID: B-62 CS Left Rm 100

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-05

Collected By: SH-Client

Collection Date: 09/24/2016 8:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0044	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1410

Client Sample ID: B-63 DF Rm 100

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-06

Collected By: SH-Client

Collection Date: 09/24/2016 8:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0056	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1414

Client Sample ID: B-64 BS Rm 110

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-07

Collected By: SH-Client

Collection Date: 09/24/2016 8:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.016	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1414



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611230

Client Sample ID: B-65 BS Rm 120

Sample Matrix: Drinking Water

Lab Sample ID: J611230-08

Collected By: SH-Client

Collection Date: 09/24/2016 8:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0064	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1415

Client Sample ID: B-66 DF Rm 120

Sample Matrix: Drinking Water

Lab Sample ID: J611230-09

Collected By: SH-Client

Collection Date: 09/24/2016 8:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0054	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1416

Client Sample ID: B-67 CS Rm 120

Sample Matrix: Drinking Water

Lab Sample ID: J611230-10

Collected By: SH-Client

Collection Date: 09/24/2016 8:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0052	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1416

Client Sample ID: B-68 BS Rm 130

Sample Matrix: Drinking Water

Lab Sample ID: J611230-11

Collected By: SH-Client

Collection Date: 09/24/2016 9:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0095	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1417



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-69 DF Rm 130

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-12

Collected By: SH-Client

Collection Date: 09/24/2016 9:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0039	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1418

Client Sample ID: B-70 CS Rm 130

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-13

Collected By: SH-Client

Collection Date: 09/24/2016 9:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0081	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1418

Client Sample ID: B-71 Old DF Rm 130

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-14

Collected By: SH-Client

Collection Date: 09/24/2016 9:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.014	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1420

Client Sample ID: B-72 Old DF Rm 120

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-15

Collected By: SH-Client

Collection Date: 09/24/2016 9:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.10	0.015	0.0010	mg/L	E	10/06/16 0815	10/13/16 1421



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-73 Old DF Rm 140

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-16

Collected By: SH-Client

Collection Date: 09/24/2016 9:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.031	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1423

Client Sample ID: B-74 BS Rm 140

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-17

Collected By: SH-Client

Collection Date: 09/24/2016 9:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0071	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1423

Client Sample ID: B-75 DF Rm 140

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-18

Collected By: SH-Client

Collection Date: 09/24/2016 9:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0098	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1424

Client Sample ID: B-76 CS Rm 140

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-19

Collected By: SH-Client

Collection Date: 09/24/2016 9:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0077	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1425



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-77 BS Rm 150

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-20

Collected By: SH-Client

Collection Date: 09/24/2016 9:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0091	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1425

Client Sample ID: B-78 CS Rm 150

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-21

Collected By: SH-Client

Collection Date: 09/24/2016 9:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1426

Client Sample ID: B-79 DF Rm 150

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-22

Collected By: SH-Client

Collection Date: 09/24/2016 9:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.016	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1428

Client Sample ID: B-80 BS Rm 160

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-23

Collected By: SH-Client

Collection Date: 09/24/2016 9:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0050	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1429



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-81 DF Rm 160

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-24

Collected By: SH-Client

Collection Date: 09/24/2016 9:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0078	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1429

Client Sample ID: B-82 CS Rm 160

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-25

Collected By: SH-Client

Collection Date: 09/24/2016 9:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0037	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1430

Client Sample ID: B-83 BS Rm 170

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-26

Collected By: SH-Client

Collection Date: 09/24/2016 9:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.010	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1432

Client Sample ID: B-84 CS Rm 170

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-27

Collected By: SH-Client

Collection Date: 09/24/2016 9:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0048	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1433



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-85 DF Fm 170

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-28

Collected By: SH-Client

Collection Date: 09/24/2016 9:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1433

Client Sample ID: B-86 BS Rm 180

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-29

Collected By: SH-Client

Collection Date: 09/24/2016 9:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.021	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1434

Client Sample ID: B-87 DF Rm 180

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-30

Collected By: SH-Client

Collection Date: 09/24/2016 9:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0066	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1439

Client Sample ID: B-88 CS Rm 190

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-31

Collected By: SH-Client

Collection Date: 09/24/2016 9:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.019	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1441



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-89 BS Rm 190

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-32

Collected By: SH-Client

Collection Date: 09/24/2016 9:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.10	0.015	0.0010	mg/L	E	10/06/16 0815	10/13/16 1442

Client Sample ID: B-90 CS Rm 190

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-33

Collected By: SH-Client

Collection Date: 09/24/2016 9:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.030	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1443

Client Sample ID: B-91 DF Rm 190

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-34

Collected By: SH-Client

Collection Date: 09/24/2016 9:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.010	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1443

Client Sample ID: B-92 Old DF Rm 220

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-35

Collected By: SH-Client

Collection Date: 09/24/2016 10:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1444

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 9 of 16



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Client Sample ID: B-93 Old DF Rm 230

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-36

Collected By: SH-Client

Collection Date: 09/24/2016 10:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1447

Client Sample ID: B-94 BS Rm 520

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-37

Collected By: SH-Client

Collection Date: 09/24/2016 10:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0095	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1448

Client Sample ID: B-95 Office Sink Rm 520

Sample Matrix: Drinking Water

Lab Sample ID: J6I1230-38

Collected By: SH-Client

Collection Date: 09/24/2016 10:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.013	0.015	0.0010	mg/L		10/06/16 0815	10/13/16 1449

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
E: Estimated result
MDL: Minimum Detection Limit
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

New York State Department of Health

PA DEP ID: 68-04863

Pennsylvania Department of Environmental Protection

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 10 of 16



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1230

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Michael Fifield
Division Manager
michael.fifield@microbac.com
10/25/2016 21:58

3021 Buick Drive
Cortland NY 13046
Phone: (607) 763-3403 Fax: (607) 763-3418
NY #10705, EPA #NY00095

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information			Billing/Invoice:	
Name: <u>CORTLAND CCSD</u>				
Address: <u>BARRY ELEM</u>				
Contact:				
Phone:				
Project:				
Quote ID:			PO#: _____	
Rush TAT Bus. Days: <2 2-5 8-7 7-10			Date Req.: _____	
Release to DOH: <u>Yes</u>				
Email Results: <u>Yes</u> <u>RMARTIN@CORTLANDSCHS.HOUS.ORG</u>				
Fax Results: <u>Yes</u> <u>KWALDBY@CORTLANDSCHS.HOUS.ORG</u>				
Sample Information				
Description	Date	Time	Initial	Matrix Type
1 <u>B-58/ Siph</u>	<u>9-24-16</u>	<u>8:37</u>	<u>SH</u>	
2 <u>B-59 D.F.</u>	<u>9-24-16</u>	<u>8:39</u>	<u>SH</u>	
3 <u>B-60 B.S.</u>		<u>8:44</u>	<u>SH</u>	
4 <u>B-61 C.S. Right</u>		<u>8:44</u>	<u>SH</u>	
5 <u>B-62 C.S. LEFT</u>		<u>8:44</u>	<u>SH</u>	
6 <u>B-63 Rm. 100</u>		<u>8:44</u>	<u>SH</u>	
7 <u>B-64 B.S.</u>		<u>8:49</u>	<u>SH</u>	
8 <u>B-65 Rm. 120</u>		<u>8:52</u>	<u>SH</u>	
Number of Containers for Analysis Requested				
Preservative				
Comments/Field Data				
Receiving Info (Lab Use Only)				
Ice: YES <u>NO</u>				
Cooler: YES <u>NO</u>				
Sample Temp: <u>22.5</u>				
Cooler Seal: YES <u>NO</u>				
Pickup: YES <u>NO</u>				
Dropoff: <u>C</u> <u>W</u>				
Accepted? YES <u>NO</u>				
Container Material				
Container Size (in Mil)				

Signature		Date/Time	Comments
Sampled: <u>STEVEN HALSLANDER/BARRY</u>		<u>9-26-16</u>	<u>9:10</u>
Received: <u>BOB MARTIN CCSSD</u>		<u>9/26/16</u>	
Received: <u>Wm Breckman</u>		<u>9-26-16</u>	<u>13:50</u>
Received:			
Received:			
Received:			



J611230

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		Analysis Requested		MNY Workorder #	
Name: <u>Cortland BCS</u>									
Address: <u>Barry Elam</u>									
Contact:									
Phone:									
Project:									
Quota ID:				PO#:					
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:					
Release to DOH: <u>Yes</u>									
Email Results: <u>Yes</u> <u>Rmartin@cortlandschools.org</u>									
Fax Results: <u>Yes</u> <u>Kwaddy@cortlandschools.org</u>									
Sample Information									
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested				
1 B-66 D.F. Rm 120	9-24-16	8:52	SH	SW					
2 B-67 C.S. Rm. 120	9-24-16	8:52	SH	Rab					
3 B-68 B-S Rm. 130	9-24-16	9:00	SH						
4 B-69 D.F. Rm. 130	9-24-16	9:00	SH						
5 B-70 C.S. Rm. 130	9-24-16	9:00	SH						
6 B-71 O.D. D.F. Rm. 130	9-24-16	9:00	SH						
7 B-72 O.D. D.F. Rm. 120	9-24-16	9:03	SH						
8 B-73 O.D. D.F. Rm. 140	9-24-16	9:08	SA	V					
Print Name and Company					Signature				
Sampled: <u>Steven Huls/Anderson Barry</u>					<u>Steven S. Huls/Anderson Barry</u>				
Received: <u>BOB MARTIN CSO</u>					<u>Bob Martin</u>				
Received: <u>Dan Benichou</u>					<u>Dan Benichou</u>				
Received:									
Received:									
Received:									
Received:									
Received:									
Date/Time					Comments				
					9-26-16 10:02				
					9-26-16 12:52				

3021 Buick Drive
Cortland NY 13045
Phone: (607) 763-3405 Fax: (607) 763-3418
NY #10705, EPA #NY00885

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #	
Name:	Cortland BOSS			Receiving Info (Lab Use Only)			
Address:	Bary Elam			Ice:	YES (NO)		
Contact:				Cooler:	YES (NO)		
Phone:				Sample Temp:	28°C		
Project:				Cooler Seal:	YES NO		
Quote ID:				Pickup:	YES NO		
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Dropoff:	C W		
Release to DOH: (Yes)				Accepted?	YES NO		
Email Results: (Yes) Rmartin@cortlandschools.org				Container Material			
Fax Results: (Yes) Kwalley@cortlandschools.org				Container Size (in Mi)			
Sample Information				Preservative			
Description	Date	Time	Initial	Number of Containers for Analysis Requested			
1 B-74 B-S	9-24-16	9:08	SH				
2 B-75 D.F.	9-24-16	9:08	SH				
3 B-76 C.S.	9-24-16	9:08	SH				
4 B-77 B-S	9-24-16	9:27	SH				
5 B-78 Rm. 150	9-24-16	9:27	SH				
6 B-79 D.F.	9-24-16	9:27	SH				
7 B-80 B-S	9-24-16	9:31	SH				
8 B-81 D.F.	9-24-16	9:31	SH				
Print Name and Company				Signature			
Sample: STEPHEN HULSTON/BOSS				Date/Time: 9-26-16-10:00			
Received: BOB MARTIN - BOSS				Signature: [Signature]			
Received: DAN BOSS				Signature: [Signature]			
Received: [Blank]				Signature: [Blank]			
Received: [Blank]				Signature: [Blank]			
Received: [Blank]				Signature: [Blank]			

3021 Buck Drive
Cortland NY 13045
Phone: (607) 763-3403 Fax: (607) 763-3418
NY #10705, EPA #NY00896

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #	
Name:	Cortland ESCD						
Address:	Bury Elam						
Contact:							
Phone:							
Project:							
Quote ID:							
Rush TAT Bus. Days:	<2	2-5	6-7	7-10	Data Req.:		
Release to DOH (Yes):							
Email Results:	Yes Rmartin@CortlandSchools.org						
Fax Results:	Yes Kwalley@CortlandSchools.org						
Sample Information							
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested		
1 B-82 C.S. Rm. 160	9-24-16	9:31	SH	SW			
2 B-83 B-S Rm. 170	9-24-16	9:35	SH	Prob			
3 B-84 C.S. Rm. 170	9-24-16	9:35	SH				
4 B-85 D.F. Rm. 170	9-24-16	9:35	SH				
5 B-86 B-S Rm. 180	9-24-16	9:45	SH				
6 B-87 O.F. Rm. 180	9-24-16	9:45	SH				
7 B-88 C.S. Rm. 180	9-24-16	9:45	SH				
8 B-89 B-S Rm. 190	9-24-16	9:57	SH	V			
Print Name and Company				Signature	Date/Time		
Sampled: Stevens Hublander / BARRY				Stevens Hublander	9-26-16 10:00		
Received: Bob Martin - ESCD				Bob Martin	9/26/16 10:00		
Received: Dan Buehler				Dan Buehler	9-26-16 12:52		
Received:							
Received:							

Receiving Info (Lab Use Only)	
Ice:	YES (NO)
Cooler:	YES (NO)
Sample Temp:	22.7
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container (Strain M)	
Preservative	
Comments/Field Data	

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:				MNY Workorder #					
Name: Cortland E.O.S.D.				Address: Barry Egan				Receiving Info (Lab Use Only)					
Contact:				Phone:				Ice: YES NO					
Project:				PO#:				Cooler: YES NO					
Quote ID:				Rush TAT Bus. Days: <2 2-5 6-7 7-10				Sample Temp: 22°C					
Release to DOH: Yes				Date Recd:				Cooler Seal: YES NO					
Email Results: Yes				Fax Results: Yes				Pickup: YES NO					
Email Results: Yes				Fax Results: Yes				Dropoff: C W					
Email Results: Yes				Fax Results: Yes				Accepted? YES NO					
Email Results: Yes				Fax Results: Yes				Container Material					
Email Results: Yes				Fax Results: Yes				Container Size (inches)					
Email Results: Yes				Fax Results: Yes				Preservative					
Email Results: Yes				Fax Results: Yes				Comments/Field Data					
Sample Information				Number of Containers for Analysis Requested									
Description/Location				Date		Time		Initial		Matrix Type			
1 B-90 C.S. RM. 190				9-24-16		9:57		SH		SW			
2 B-91 D.F. RM. 190				9-24-16		9:57		SH		Bab			
3 B-92 O.F. (LOW) RM. 220				9-24-16		10:02		SH					
4 B-93 O.D. D.F. RM. 230				9-24-16		10:04		SH					
5 B-94 RM. 520 OFFICE SINK				9-24-16		10:09		SH					
6 B-95 RM. 520				9-24-16		10:09		SH					
7													
8													
Print Name and Company				Signature		Date/Time		Comments					
Sampled: Steven Huls/Alden/BARR				Steven Huls/Alden		9-26-16 10:05							
Received: BOB MARRIN C.E.S.D.				BOB MARRIN		9/26/16 10:02							
Received: NINA RICHMOND				NINA RICHMOND		9-26-16 10:52							
Received:													
Received:													
Received:													