MICROBAC®

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7E1553

Cortland City School District

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project Name: Barry Elementary

Project / PO Number: N/A
Received: 05/24/2017 10:55
Reported: 05/31/2017 14:25

Analytical Testing Parameters

Client Sample ID: B-89 Room 190 BS (Retest)
Lab Sample ID: J7E1553-01
Sample Type: Grab

Collected By: NH-Client
Collection Date: 05/24/17
Collection Time: 06:14

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	**0.0511**	0.0150	0.000500	mg/L	**G**	05/25/17 1452	05/26/17 1352	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 22.0°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795 New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
05/31/2017 14:25

Go Green: Contact Andrew Canale to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Christine Pechacek, Laboratory Director at christine.pechacek@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3821 Buck Drive
Cortland NY 13045
Phone:(607)753-3403 Fax:(607)753-3415
NY #10795, EPA #NY00935

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Client Information	Billing/Invoice:
Name: Barry Elementary	
Address: 1 Valley View Drive Cortland, NY 13045	
Contact: Neal Helms	
Phone: 607-345-4147	
Project: Lead	
Quote ID:	PO#:

Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req.:

Release to DOH: Yes

Email Results: Yes nhelms@cortlandschools.org

Fax Results: Yes

Analysis Requested: Lead

Receiving Info (Lab Use Only)		
Ice:	YES	NO
Cooler:	YES	NO
Sample Temp:	22.0	
Cooler Seal:	YES	NO
Pickup:	YES	NO
Dropoff:	C	W
Accepted?	YES	NO

Container Material

Container Size(in Ml)

Preservative

Sample Information

	Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Comments/Fi
1	B-89 Room 190 BS retest	6/24/17	6:14	NH	DW	1	
2							
3							
4							
5							
6							
7							
8							

	Print Name and Company	Signature	Date/Time
Sampled:	Neal Helms Cortlandschool	Neal Helms	6/24/17 6:30 pm
Received:	Cayla Aldrich CA	Cayla A	6/24/17 10:55
Received:			
Received:			
Received:			
Received:			

Comments

PLACE ALL SAMPLES IN BAGS WITH ICE.

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

J7E1553