



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0617

Cortland City School District

Project Name: Barry School

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 12/08/2016 11:05
Reported: 12/30/2016 16:13

Analytical Testing Parameters

Client Sample ID: B-96 Room 550 Bathroom Sink
Lab Sample ID: J6L0617-01
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.013		0.001	mg/L		12/19/16 0853	12/28/16 1251

Analytical Testing Parameters

Client Sample ID: B-97 Room 550 Kitchen Sink
Lab Sample ID: J6L0617-02
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0071		0.001	mg/L		12/19/16 0853	12/28/16 1250

Analytical Testing Parameters

Client Sample ID: B-98 Room 470 Dish Room
Lab Sample ID: J6L0617-03
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.013		0.001	mg/L		12/19/16 0853	12/28/16 1255

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 7



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0617

Analytical Testing Parameters

Client Sample ID: B-99 Hand Room 470 Hand Wash Sink
Lab Sample ID: J6L0617-04
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.069		0.001	mg/L	G	12/19/16 0853	12/28/16 1257

Analytical Testing Parameters

Client Sample ID: B-100 Room 470 Left Prep Sink
Lab Sample ID: J6L0617-05
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.031		0.001	mg/L	G	12/19/16 0853	12/28/16 1259

Analytical Testing Parameters

Client Sample ID: B-101 Room 470 Right Prep Sink
Lab Sample ID: J6L0617-06
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.01		0.001	mg/L		12/19/16 0853	12/28/16 1300



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0617

Analytical Testing Parameters

Client Sample ID: B-102 Room 415 Sink Cafe
Lab Sample ID: J6L0617-07
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0048		0.001	mg/L		12/19/16 0853	12/28/16 1306

Analytical Testing Parameters

Client Sample ID: B-103 Room 400D Girls L.R. Left Sink
Lab Sample ID: J6L0617-08
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0081		0.001	mg/L		12/19/16 0853	12/28/16 1308

Analytical Testing Parameters

Client Sample ID: B-104 Right Sink Girls L.R.
Lab Sample ID: J6L0617-09
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0055		0.001	mg/L		12/19/16 0853	12/28/16 1310



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0617

Analytical Testing Parameters

Client Sample ID: B-105 Boys L.R. Sink
Lab Sample ID: J6L0617-10
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0012		0.001	mg/L		12/19/16 0853	12/28/16 1311

Analytical Testing Parameters

Client Sample ID: B-106 Room 480 B.S.
Lab Sample ID: J6L0617-11
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 06:57

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0059		0.001	mg/L		12/19/16 0853	12/28/16 1052

Analytical Testing Parameters

Client Sample ID: B-107 Boys B.S. Outside
Lab Sample ID: J6L0617-12
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0026		0.001	mg/L		12/19/16 0853	12/28/16 1054



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0617

Analytical Testing Parameters

Client Sample ID: B-108 Girls B.S. Outside
Lab Sample ID: J6L0617-13
Sample Type: Grab

Collected By: SH-Client
Collection Date: 12/07/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0043		0.001	mg/L		12/19/16 0853	12/28/16 1055

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
G: Result fails applicable NYS drinking water standards
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. Dayville (NY 11549)

NY Lab ID No: 11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
12/30/2016 16:13

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested				Receiving Info (Lab Use Only)				
Name:	C BCSO			Address:	Barnet			Project:	Quote ID:	PO#:	Date Recd.:	Ice:	YES NO	
Contact:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Cooler:	YES NO	
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Sample Temp:		
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Cooler Seal:	YES NO	
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Pickup:	YES NO	
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Dropoff:	C W	
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Accepted?	YES NO	
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Container Material		
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Container Size (in MI)		
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Preservative		
Project:				Phone:				Project:	Quote ID:	PO#:	Date Recd.:	Comments/Field Data		
1	B-96	BATHROOM	12-7-16	6:55	SA									
2	B-97	KITCHEN	12-7-16	6:18	SA									
3	B-98	DISH ROOM	12-7-16	6:20	SA									
4	B-99	HAND WASH	12-7-16	6:24	SA									
5	B-100	LEFT PREP	12-7-16	6:30	SA									
6	B-101	RIGHT PREP	12-7-16	6:32	SA									
7	B-102	SINK-CAFE	12-7-16	6:34	SA									
8	B-103	SINKS L.R.	12-7-16	6:42	SA									
9	B-104	LEFT SINK	12-7-16	6:42	SA									

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Bob Martin C BCSO	Bob Martin	12/8/16 11:45	
Received:	Haywood Dawson	Haywood Dawson	12/8/16 11:05	
Received:				
Received:				
Received:				
Received:				



J6L0617

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:		Analysts Requested		Receiving Info (Lab Use Only)	
Name:	CROD						Ice:	YES NO
Address:	Barry						Cooler:	YES NO
Contact:							Sample Temp:	
Phone:							Cooler Seal:	YES NO
Project:							Pickup:	YES NO
Quote ID:							Dropoff:	C W
Rush TAT Bus. Days:	<2	2-5	5-7	7-10	Date Req.:		Accepted?	YES NO
Release to DOH:	Yes						Container Material	
Email Results:	R.Dawson@CortlandNY.gov						Container Size (in ml)	
Fax Results:	KUNDBY@CortlandNY.gov						Preservative	
Sample Information								
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested			
1 B-104 RIG-HIT SINK	12-7-16	6:46	SA	DW	1			
2 B-105 GIRLS L.R.	12-7-16	6:52	SA		1			
3 B-106 BOYS L.R.	12-7-16	6:57	SA		1			
4 B-107 Rm. 980	12-7-16	7:00	SA		1			
5 B-108 B.S.	12-7-16	7:05	SA		1			
6 B-109 DUTSIDE								
7								
8								

Print Name and Company	Signature	Date/Time	Comments
Sampled: R.Dawson - CROD	[Signature]	12/8/16 11:05	
Received: Raymond Dawson	[Signature]	12/8/16 11:05	
Received:			
Received:			
Received:			
Received:			