



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A1390

Cortland City School District

Project Name: Lead Analysis-Parker School

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 01/27/2017 10:40  
Reported: 02/13/2017 10:36

Analytical Testing Parameters

Client Sample ID: P-58 Room 111F Bathroom Sink  
Lab Sample ID: J7A1390-01  
Sample Type: Grab

Collected By: KB-Client  
Collection Date: 01/26/17  
Collection Time: 06:15

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4							Method Notes: X	
Lead	0.0175	0.0150	0.000500	mg/L	G	01/27/17 1317	02/08/17 1632	NY

Analytical Testing Parameters

Client Sample ID: P-63 Room 121 Classroom Sink  
Lab Sample ID: J7A1390-02  
Sample Type: Grab

Collected By: KB-Client  
Collection Date: 01/26/17  
Collection Time: 06:20

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00294	0.0150	0.000500	mg/L		01/27/17 1317	02/08/17 1632	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level  
RL: Reporting Limit  
X: Exceeds regulatory limit.  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A1390

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

Andrew Canale  
Project Manager  
02/13/2017 10:36

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options .

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

3821 Buck Drive  
Cortland NY 13045  
Phone: (607) 763-3403 Fax: (607) 763-3415  
NY #10795, EPA #NY00895

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #	
Name: PARKER SCHOOL							
Address: MADISON ST CORTLAND, NY 13043							
Contact: BOB MARTIN							
Phone: 758-4127							
Project:							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes				R. MARTIN@CORTLANDSCHOOL.ORG			
Fax Results: Yes							
Sample Information				Analysts Requested			
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested		
1 P-58 Room 1115 Bathroom Sink	1/26/17	6:15 AM	KB	DW			
2 P-63 Room 121 classroom Sink	1/26/17	6:20 AM	KB	DW			
3							
4							
5							
6							
7							
8							
Print Name and Company				Signature		Date/Time	
Sampled: Keith Bergeron				[Signature]		1/26/17 6:30 AM	
Received: BOB MARTIN CIESO				[Signature]		1/27/17 10:20	
Received: Alexander Dawson				[Signature]		1/27/17 10:40	
Received:							
Received:							
Received:							

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container Size (in Ml)	
Preservative	
Comments/Field Data	



J7A1390