



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7B0783

Cortland City School District

Project Name: Parker Elementary

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 02/10/2017
Reported: 02/16/2017

Analytical Testing Parameters

Client Sample ID: P-69 Room 117 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J7B0783-01

Collected By: KB-Client
Collection Date: 02/10/2017 7:30

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	0.0174	0.015 AL	0.000500	mg/L		02/13/17 1155	02/15/17 0911	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Andrew Canale
Project Manager
andrew.canale@microbac.com
02/16/2017 16:59

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 2

