



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7I0862

Cortland City School District

Project Name: Lead Analysis

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 09/08/2017 13:34  
Reported: 09/20/2017 09:02

Analytical Testing Parameters

Client Sample ID: HS-149 Consession Stand Hose Bib  
Lab Sample ID: J7I0862-01  
Sample Type: Grab

Collected By: NH-Client  
Collection Date: 09/08/17  
Collection Time: 13:24

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.00749	0.0150	0.000500	mg/L		09/13/17 1100	09/15/17 1707	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level  
RL: Reporting Limit  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 21.6°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Alayna Dawson  
Administrative Assistant  
09/20/2017 09:02

**Go Green:** Contact Alayna Dawson to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Alayna Dawson, Project Manager at alayna.dawson@microbac.com. You may also contact Christine Pechacek, Laboratory Director at christine.pechacek@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Cortland Schools / Concession Stand								Ice: YES NO	
Address: 1 Valley View Drive								Cooler: YES NO	
Cortland, NY 13045								Sample Temp: 21.6	
Contact: Neal Helms								Cooler Seal: YES NO	
Phone: 607-345-4147								Pickup: YES NO	
Project: lead								Dropoff: C W	
Quote ID: PO#:								Accepted? YES NO	
Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req.:								Container Material	
Release to DOH: Yes								Container Size (in Mil)	
Email Results: Yes <u>whelms@cortlandschools.org</u>								Preservative	
Fax Results: Yes									
Sample Information				Matrix		Number of Containers for Analysis Requested		Comments	
Description/Location	Date	Time	Initial	Type					
1 HS-149 Concession Stand Horse Bldg	9/8/17	1:27pm	NH	DW	1				
2									
3									
4									
5									
6									
7									
8									
Print Name and Company				Signature		Date/Time		Comments	
Sampled: Neal Helms Cortland Schools				Neal Helms		9/8/17 1:27pm		***PLACE ALL SAMPLES IN BAGS WITH ICE, ***	
Received: Dorothy Nashel				Dorothy Nashel		9-8-17 1:34			
Received:									
Received:									
Received:									
Received:									
<p>Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.</p> <p style="text-align: right;">CAPP on file</p>									