



Cortland Enlarged City School District Lead Testing

| Building | # of Samples Submitted | # of Results Received | # of Samples Above 15 ppb. | Location | Remediation |
|---------------|------------------------|-----------------------|----------------------------|---|--|
| Randall Elem. | 47 | 47 | 2 | Kitchen hand wash sink Room 115 sink | Post not for drinking, replace and retest. Replace and retest |