

## Lead sample Building Data

Revised 1/23/17

Building	# of Samples Submitted	# of Results Received	# of Samples Above 15 ppb.	Location	Remediation
Barry Elem.	95	95	21	Room 200 Bathroom sink	Replace and retest - repaired
				Room 230 Bathroom sink	Replace and retest- repaired
				Room 230 Drinking fountain	Replace and retest- repaired
				Room 240 Bathroom sink	Replace and retest
				Room 240 classroom sink	Repair and replace- repaired
				Room 240 drinking fountain	Repair and replace- repaired
				Room 250 Bathroom sink	Replace and repair
				Room 260 Bathroom sink	Replace and retest- repaired
				Room 270 Bathroom sink	Replace and retest- repaired
				Hallway drinking fountain	Replace and retest
				Room 110 Bathroom sink	Replace and retest- repaired
				Room 120 drinking fountain	Removed -done
				Room 140 drinking Fountain	Removed -done

## Lead sample Building Data

Revised 1/23/17

				Room 150 drinking fountain	Replace and retest- repaired
				Room 180 Bathroom sink	Replace and retest- repaired
				Room 180 Classroom sink	Replace and retest- repaired
				Room 190 Bathroom sink	Replace and retest- repaired
				Room 190 Classroom sink	Replace and retest- repaired
				Room 220 drinking fountain	Remove -done
				Room 230 drinking fountain	Remove - done
				Room 350 drinking fountain	Replace and retest- repaired
Parker Elem.	75	75	4	Room 111F sink	Replace and retest- repaired
				Room 111D sink	Replace and retest- repaired
				Room 121 sink	Replace and retest- repaired
				Room 117	Replace and retest
Randall Elem.	47	47	2	Kitchen hand wash sink	Post not for drinking, replace and retest.- repaired
				Room 115 sink	Replace and retest- repaired

## Lead sample Building Data

Revised 1/23/17

Smith Elem.	99	99	26	Room 300 Hand Wash Sink	Older faucet (Replace & Retest)- repaired
				Room 300 Sink 1	Sink 2 test ok next to Sink 1, earlier tested was ok (Replace & Retest)- repaired
				Room 310 Bath Sink	Older faucet (Replace & Retest)
				Room 360 Bath & Room Sinks	Older faucet (Replace & Retest)- repaired
				Room 370 Sink, Older Dental Sink	Older Dental Sink (Remove fixture)-done
				Room 400A Bath Sink	Newer faucet, reading not that high (Retest)
				Room 502 Room Sink	Drinking Fountain on one side & Bath Sink on the other side of Room Sink tested low, all new fixtures, doesn't make sense Room Sink testing about five times what other two tested (Retest)
				Room 504 Bath Sink	Older faucet, flow issue, faucet is not use & water is off (Replace & Retest)
				Room 20 Bath room sink	Older faucet (Replace & Retest)
				Room 20 class sink	Older faucet (Replace & Retest)
				Room 30 class sink	Older faucet (Replace & Retest)

## Lead sample Building Data

Revised 1/23/17

				Room 40 bath room sink	Older faucet (Replace & Retest)
				Room 40 class sink	Older faucet (Replace & Retest)
				Room 26 class sink	Older faucet (Replace & Retest)
				Room 120drinking fountain	Replace and retest
				Room 130 class sink	Older faucet (Replace & Retest)
				Room 120 class sink	Older faucet (Replace & Retest)
				Room 150 bath room sink	Older faucet (Replace & Retest)
				Room 160 bath room sink	Older faucet (Replace & Retest)
				Room 170 bath room sink	Older faucet (Replace & Retest)
				Room 180 bath room sink	Older faucet (Replace & Retest)
				Room 190 bath room sink	Older faucet (Replace & Retest)
				Room 200 bath sink	Older faucet (Replace & Retest)
				Room 220 sink	Older faucet (Replace & Retest)

## Lead sample Building Data

Revised 1/23/17

				Room Girls locker office bath room	Older faucet (Replace & Retest)
Virgil Elem.	45	45	2	Classroom #6 - Sink	Faucet, supply lines and piping have been removed and will be replaced.- repaired
				Classroom #27 – Sink Installed new bubbler	Faucet, supply lines and piping have been removed and will be replaced.- repaired Installed
JSHS	139	137	22	Bathroom sink - room 162	Left & center faucet - Faucet, supply lines and piping have been removed and will be replaced.
				Girls room 232 – Left sink	Replace & retest
				Boys room 230 – Left sink	Replace & retest
				Bathroom 210 – left sink	Replace & retest
				Room 207	Replace & retest
				Boys bathroom 252 Left	Replace & retest
				Room 261 sink	Replace & retest
				Room 265 sink	Replace & retest
				Room 267 sink	Replace & retest
				Girls bathroom – 253 right	Replace & retest
				Room 253 bathroom middle	Replace & retest
				Room 253 bathroom left	Replace & retest

Lead sample Building Data

Revised 1/23/17

				Room 167 Right sink	Review classroom use – lab or not?
				Room 190C	Not to be used for drinking water – private office bathroom
				Room 90 sink	Shop class do not use for drinking water
				Room 85 Right sink	Replace & retest
				Room 92 sink	Shop class do not use for drinking water
				Room 92 Drinking fountain	Remove
				Room 95A sink	Shop class do not use for drinking water
				Room 81A	Replace & retest
				Room 57C	Not to be used for drinking water – private office bathroom