



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0234

Cortland City School District

Project Name: Lead Analysis

Bob Martin  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 03/01/2017 10:50  
Reported: 03/08/2017 17:13

Analytical Testing Parameters

Client Sample ID: P-58 Room 111F Bathroom Sink  
Lab Sample ID: J7C0234-01  
Sample Type: Grab

Collected By: RB-Client  
Collection Date: 02/28/17  
Collection Time: 06:00

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0198	0.0150	0.000500	mg/L	G	03/02/17 1407	03/03/17 1446	NY

Analytical Testing Parameters

Client Sample ID: P-69 Room 117 Sink  
Lab Sample ID: J7C0234-02  
Sample Type: Grab

Collected By: RB-Client  
Collection Date: 02/28/17  
Collection Time: 06:02

Lead and/or Copper, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8, Rv 5.4								
Lead	0.0104	0.0150	0.000500	mg/L		03/02/17 1407	03/03/17 1446	NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level  
RL: Reporting Limit  
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0234

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

Andrew Canale  
Project Manager  
03/08/2017 17:13

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options .

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

MNY Workorder #

J7C0234

Client Information				Billing/Invoice:		Analysis Requested				Receiving Info (Lab Use Only)	
Name: PARKER SEWELL										Ice: YES NO	
Address: MADISON ST										Cooler: YES NO	
Contact: CROSBY										Sample Temp: YES NO	
Phone:										Cooler Seal: YES NO	
Project:										Pickup: YES NO	
Quote ID:				PO#:						Dropoff: C W	
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Date Req.:						Accepted? YES NO	
Release to DOH: Yes										Container Material	
Email Results: Yes				Rmartin@corlundschoos.org / Knowledge@						Container Size (in Mil)	
Fax Results: Yes										Preservative	
Sample Information				Matrix		Number of Containers for Analysis Requested				Comments/Field Data	
Description/Location	Date	Time	Initial	Type							
1 P-58 Room 111F Bottom Sink	2/25/17	6:30AM	NR	DW							
2 P-69 Room 111 Sink	2/25/17	6:30AM	NR	Grab							
3											
4											
5											
6											
7											
8											
Print Name and Company				Signature		Date/Time		Comments			
Sampled: Kelly Byron Parker				<i>[Signature]</i>		2/25/17 6:30AM					
Received: BOB MARTIN, CROSBY				<i>[Signature]</i>		2/25/17 10:50					
Received: Hayman Dawson				<i>[Signature]</i>		2/25/17 10:50					
Received:											
Received:											
Received:											

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.