



## Cortland Enlarged City School District Lead Testing

Building	# of Samples Submitted	# of Results Received	# of Samples Above 15 ppb.	Location	Remediation
Parker Elem.	75	75	4	Room 111F sink	Replace and retest
				Room 111D sink	Replace and retest
				Room 121 sink	Replace and retest
				Room 117	Replace and retest



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Cortland City School District

Project Name: Parker Elementary School

Neal Helms  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 09/21/2016  
Reported: 10/19/2016

Analytical Testing Parameters

Client Sample ID: P-1 Room 201 Bathroom  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1104-01

Collected By: KB-Client  
Collection Date: 09/21/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1443

Client Sample ID: P-2 Room 201 Drinking Fountain  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1104-02

Collected By: KB-Client  
Collection Date: 09/21/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1443

Client Sample ID: P-3 Room 202 Bathroom  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1104-03

Collected By: KB-Client  
Collection Date: 09/21/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0042	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1444

Client Sample ID: P-4 Room 202 Drinking Fountain  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1104-04

Collected By: KB-Client  
Collection Date: 09/21/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1445

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-5 Room 203 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-05

Collected By: KB-Client

Collection Date: 09/21/2016 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1447

Client Sample ID: P-6 2nd Floor Boys Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-06

Collected By: KB-Client

Collection Date: 09/21/2016 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.012	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1449

Client Sample ID: P-7 Room 208 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-07

Collected By: KB-Client

Collection Date: 09/21/2016 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0032	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1449

Client Sample ID: P-8 Room 208 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J611104-08

Collected By: KB-Client

Collection Date: 09/21/2016 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1450



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-9 Room 205 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-09

Collected By: KB-Client

Collection Date: 09/21/2016 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0026	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1451

Client Sample ID: P-10 Room 205 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-10

Collected By: KB-Client

Collection Date: 09/21/2016 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0031	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1451

Client Sample ID: P-11 Room 210 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-11

Collected By: KB-Client

Collection Date: 09/21/2016 6:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0019	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1452

Client Sample ID: P-12 Room 219 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-12

Collected By: KB-Client

Collection Date: 09/21/2016 6:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0019	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1453



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-13 Room 207 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-13

Collected By: KB-Client

Collection Date: 09/21/2016 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0067	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1455

Client Sample ID: P-14 Room 207 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-14

Collected By: KB-Client

Collection Date: 09/21/2016 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0066	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1455

Client Sample ID: P-15 Room 209 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-15

Collected By: KB-Client

Collection Date: 09/21/2016 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1456

Client Sample ID: P-16 Room 209 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-16

Collected By: KB-Client

Collection Date: 09/21/2016 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1458



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-17 2nd Floor Staff Bathroom

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-17

Collected By: KB-Client

Collection Date: 09/21/2016 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0030	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1458

Client Sample ID: P-18 Room 230 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-18

Collected By: KB-Client

Collection Date: 09/21/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0014	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1459

Client Sample ID: P-19 Room 230 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-19

Collected By: KB-Client

Collection Date: 09/21/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0013	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1500

Client Sample ID: P-20 Room 230 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-20

Collected By: KB-Client

Collection Date: 09/21/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0073	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1500



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-21 Room 232 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-21

Collected By: KB-Client

Collection Date: 09/21/2016 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0024	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1502

Client Sample ID: P-22 Room 232 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-22

Collected By: KB-Client

Collection Date: 09/21/2016 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0016	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1503

Client Sample ID: P-23 Room 232 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-23

Collected By: KB-Client

Collection Date: 09/21/2016 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/07/16 0817	10/10/16 1539

Client Sample ID: P-24 2nd Floor Girls Bathroom

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-24

Collected By: KB-Client

Collection Date: 09/21/2016 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0075	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1504





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-25 Room 220 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-25

Collected By: KB-Client

Collection Date: 09/21/2016 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1504

Client Sample ID: P-26 Room 220 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J611104-26

Collected By: KB-Client

Collection Date: 09/21/2016 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1506

Client Sample ID: P-27 Room 220 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-27

Collected By: KB-Client

Collection Date: 09/21/2016 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1507

Client Sample ID: P-28 Room 221 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J611104-28

Collected By: KB-Client

Collection Date: 09/21/2016 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0044	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1508





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-29 Room 221 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-29

Collected By: KB-Client

Collection Date: 09/21/2016 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.013	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1508

Client Sample ID: P-30 Room 221 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-30

Collected By: KB-Client

Collection Date: 09/21/2016 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1510

Client Sample ID: P-31 Room 211 Sink on Left

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-31

Collected By: KB-Client

Collection Date: 09/21/2016 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0076	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1511

Client Sample ID: P-32 Room 211 Sink on Right

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-32

Collected By: KB-Client

Collection Date: 09/21/2016 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1512



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-33 Room 213 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-33

Collected By: KB-Client

Collection Date: 09/21/2016 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0054	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1512

Client Sample ID: P-34 Room 213 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-34

Collected By: KB-Client

Collection Date: 09/21/2016 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0036	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1513

Client Sample ID: P-35 Room 215 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-35

Collected By: KB-Client

Collection Date: 09/21/2016 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1514

Client Sample ID: P-36 Room 215 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-36

Collected By: KB-Client

Collection Date: 09/21/2016 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0046	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1516

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 9 of 16



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-37 Room 216 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-37

Collected By: KB-Client

Collection Date: 09/21/2016 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0089	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1516

Client Sample ID: P-38 Room 216 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-38

Collected By: KB-Client

Collection Date: 09/21/2016 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1518

Client Sample ID: P-39 Drinking Fountain in Hallway by Room 214

Sample Matrix: Drinking Water

Lab Sample ID: J6I1104-39

Collected By: KB-Client

Collection Date: 09/21/2016 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0017	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1519

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level

MDL: Minimum Detection Limit

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

New York State Department of Health

PA DEP ID: 68-04863

Pennsylvania Department of Environmental Protection



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

*Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

**Reviewed and Approved By:**

Christine Pechacek For Michael Fifield  
Division Manager  
michael.fifield@microbac.com  
10/19/2016 12:24

3921 Buck Drive  
Cortland NY 13045  
Phone: (607) 768-3408 Fax: (607) 768-3416  
NY #10706, EPA #NY000955

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analyte Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD							Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Address:	Parker Elem							Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Contact:								Sample Temp:	21.0
Phone:								Cooler Seal:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 6-7 7-10							Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Release to DOH:	Yes							Container Material:	
Email Results:	Yes							Container Size (in Mi):	
Print Results:	Yes							Preservative:	
Sample Information				Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type				
1 P-01 Room 201 bathroom	9/26/16	6:15 PM	MS	DW					
2 -02 Room 201 Drinking fountain		6:10 PM	MS						
3 -03 Room 202 bathroom		6:15 PM	MS						
4 -04 Room 202 Drinking fountain		6:15 PM	MS						
5 -05 Room 203 sink		6:14 PM	MS						
6 -06 2nd floor boys bathroom sink		6:15 PM	MS						
7 -07 Room 208 sink		6:21 PM	MS						
8 -08 Room 208 Drinking fountain		6:21 PM	MS						
Print Name and Company						Signature			
Sampled: Keth Bogen Cortland CH Schools						Date/Time: 9/26/16 1:35 PM			
Received: BOB MARRIN ECSD						Date/Time: 9/26/16 12:45			
Received: Jennifer Walker MTS						Date/Time: 9/26/16 1:40			
Received:									
Received:									
Received:									

3021 Buck Drive  
Cortland NY 13045  
Phone: (607) 763-3003 Fax: (607) 763-3415  
NY #10795, EPA #NY00535

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analyte Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD							Ice:	YES NO
Address:	Parker Etern							Cooler:	YES NO
Contact:								Sample Temp:	
Phone:								Cooler Seal:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days: <2 2-5 5-7 7-10								Accepted?	YES NO
Release to DOH: <input checked="" type="checkbox"/>								Container Material	
Email Results: <input checked="" type="checkbox"/> <u>Yes</u>								Container Size (in Mil)	
Fax Results: <input checked="" type="checkbox"/> <u>Yes</u>								Preservative	
Sample Information				Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type					
1 P-09 Run 205 Sink	9/21/16	6:45A	KR	DW					
2 -10 Run 205 Drinking Fentley		6:45A	KR						
3 -11 Run 210 Sink		6:45A	KR						
4 -12 Run 210 Drinking Fentley		6:45A	KR						
5 -13 Run 207 Sink		6:45A	KR						
6 -14 Run 207 Drinking Fentley		6:45A	KR						
7 -15 Run 209 Sink		6:45A	KR						
8 -16 Run 209 Drinking Fentley		6:45A	KR						
Print Name and Company				Signature		Date/Time		Comments	
Sampled: Kerf Borm Cortland City Schol				<i>[Signature]</i>		9/21/16 7:54A			
Received: Bob Martin ECSD				<i>[Signature]</i>		9/21/16 12:15			
Received: Jennifer Walker MTS				<i>[Signature]</i>		9/21/16 1400			
Received:									
Received:									
Received:									

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoicing:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Address:	Contact:	Phone:	Project:	Quote ID:	Rush TAT Bus. Days: <2 2-5 6-7 7-10	Date Req.:	PO#:	Ice: YES NO
Cartland ECSD	Parker Elem								Cooler: YES NO
									Sample Temp: YES NO
									Cooler Seal: YES NO
									Pickup: YES NO
									Dropoff: C W
									Accepted? YES NO
									Container Material
									Container Size (in ml)
									Preservative
									Comments/Field Data
<b>Sample Information</b> Description/Location Date Time Initial Type Matrix 1 P-17 2nd Floor 6/21/16 6:38 AM K1 DW 2 -18 Room 230 6:41 AM K1 3 -19 Room 230 6:41 AM K1 4 -20 Room 230 6:41 AM K1 5 -21 Room 232 6:44 PM K1 6 -22 Room 232 6:45 PM K1 7 -23 Room 232 6:46 PM K1 8 -24 Girls Bottom Sink 6:46 PM K1						Number of Containers for Analysis Requested 1			
<b>Print Name and Company</b> Sampled: Karl Bergen Cortland City Schools Received: Barbara C. C. S. D. Received: Jennifer Walker Received: Received: Received:						<b>Signature</b> 6/21/16 7:35 AM 6/21/16 12:45 6/21/16 1:00			



3021 Buick Drive  
 Cortland NY 13045  
 Phone: (607) 763-3403 Fax: (607) 763-3415  
 NY #10705, EPA #NY00035

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analyte Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD			Address:	Parker Etern	Project:	PO#:	Rush TAT Bus. Days: <2 2-5 5-7 7-10	Date Rec.:
Contact:				Phone:				Release to DOH: <input checked="" type="checkbox"/> Yes	
Project:				Quote ID:				Small Results: <input checked="" type="checkbox"/> Yes	Lab Results: <input checked="" type="checkbox"/> Yes
Sample Information				Matrix		Number of Containers for Analysis Requested		Container Material	
Description/Location	Date	Time	Initial	Type			Accepted?	YES	NO
1 P-25 Run 220 Sink	9/21/16	6:51 AM	K17	DW					
2 -20 Drink Fentry		6:51 AM	K13						
3 -23 Bottom Sink		6:51 AM	K17						
4 -24 Sink		6:51 AM	K17						
5 -29 Drink Fentry		6:51 AM	K17						
6 -30 Bottom Sink		6:51 AM	K17						
7 -31 Sink on left		6:51 AM	K13						
8 -32 Sink on Right		6:51 AM	K17						
Print Name and Company				Signature		Date/Time		Comments	
Sampled: Keri Dyer Cortland City Schools				Keri Dyer		9/21/16 7:54 AM			
Received: Bob Maxon CACS				Bob Maxon		9/21/16 12:05			
Received: Jennifer Walker Mt. Carmel Hall				Jennifer Walker		9/21/16 1400			
Received:									
Received:									
Received:									





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Cortland City School District

Project Name: Parker Elementary

Neal Helms  
1 Valley View Drive  
Cortland, NY 13045

Project / PO Number: N/A  
Received: 09/22/2016  
Reported: 10/26/2016

Analytical Testing Parameters

Client Sample ID: P-40 Main Office Bathroom Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J61126-01

Collected By: KB-Client  
Collection Date: 09/22/2016 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0756

Client Sample ID: P-41 Nurse's Office Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J61126-02

Collected By: KB-Client  
Collection Date: 09/22/2016 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0016	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0756

Client Sample ID: P-42 Nurse's Office Bathroom Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J61126-03

Collected By: KB-Client  
Collection Date: 09/22/2016 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0021	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0757

Client Sample ID: P-43 Girls Bathroom Sink 1st Floor  
Sample Matrix: Drinking Water  
Lab Sample ID: J61126-04

Collected By: KB-Client  
Collection Date: 09/22/2016 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0065	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0757

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 15



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-44 Drinking Fountain by Room 109

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-05

Collected By: KB-Client

Collection Date: 09/22/2016 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0067	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0759

Client Sample ID: P-45 Room 109 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-06

Collected By: KB-Client

Collection Date: 09/22/2016 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0800

Client Sample ID: P-46 Room 111 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-07

Collected By: KB-Client

Collection Date: 09/22/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0050	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0801

Client Sample ID: P-47 Room 111A Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-08

Collected By: KB-Client

Collection Date: 09/22/2016 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0060	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0801



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Client Sample ID: P-48 Room 108 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J61126-09

Collected By: KB-Client

Collection Date: 09/22/2016 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0059	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0802

Client Sample ID: P-49 Room 108 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J61126-10

Collected By: KB-Client

Collection Date: 09/22/2016 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0061	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0803

Client Sample ID: P-50 Drinking Fountain by Room 108

Sample Matrix: Drinking Water

Lab Sample ID: J61126-11

Collected By: KB-Client

Collection Date: 09/22/2016 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0024	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0803

Client Sample ID: P-51 Room 130 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J61126-12

Collected By: KB-Client

Collection Date: 09/22/2016 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0804



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-52 Room 130 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-13

Collected By: KB-Client

Collection Date: 09/22/2016 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0805

Client Sample ID: P-53 Room 130 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-14

Collected By: KB-Client

Collection Date: 09/22/2016 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0017	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0805

Client Sample ID: P-54 Room 132 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-15

Collected By: KB-Client

Collection Date: 09/22/2016 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0023	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0807

Client Sample ID: P-55 Room 132 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-16

Collected By: KB-Client

Collection Date: 09/22/2016 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0808



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-56 Room 132 Bathroom Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1126-17

Collected By: KB-Client  
Collection Date: 09/22/2016 6:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0809

Client Sample ID: P-57 Room 111B Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1126-18

Collected By: KB-Client  
Collection Date: 09/22/2016 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0026	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0809

Client Sample ID: P-58 Room 111F Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1126-19

Collected By: KB-Client  
Collection Date: 09/22/2016 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.019	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0810

Client Sample ID: P-59 Room 111D Sink  
Sample Matrix: Drinking Water  
Lab Sample ID: J6I1126-20

Collected By: KB-Client  
Collection Date: 09/22/2016 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0811





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-60 Room 120 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-21

Collected By: KB-Client

Collection Date: 09/22/2016 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0811

Client Sample ID: P-61 Room 120 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-22

Collected By: KB-Client

Collection Date: 09/22/2016 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0029	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0812

Client Sample ID: P-62 Room 120 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-23

Collected By: KB-Client

Collection Date: 09/22/2016 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0022	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0813

Client Sample ID: P-63 Room 121 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-24

Collected By: KB-Client

Collection Date: 09/22/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0813

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 6 of 15



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-64 Room 121 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-25

Collected By: KB-Client

Collection Date: 09/22/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0023	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0815

Client Sample ID: P-65 Room 121 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-26

Collected By: KB-Client

Collection Date: 09/22/2016 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0816

Client Sample ID: P-66 Room 15 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-27

Collected By: KB-Client

Collection Date: 09/22/2016 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0030	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0817

Client Sample ID: P-67 Room 115 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-28

Collected By: KB-Client

Collection Date: 09/22/2016 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0027	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0817



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-68 Room 115 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-29

Collected By: KB-Client

Collection Date: 09/22/2016 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0040	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0818

Client Sample ID: P-69 Room 117 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-30

Collected By: KB-Client

Collection Date: 09/22/2016 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0819

Client Sample ID: P-70 Room 117 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-31

Collected By: KB-Client

Collection Date: 09/22/2016 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0819

Client Sample ID: P-71 Room 119 Sink

Sample Matrix: Drinking Water

Lab Sample ID: J6I1126-32

Collected By: KB-Client

Collection Date: 09/22/2016 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0035	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0820



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Client Sample ID: P-72 Room 119 Drinking Fountain

Sample Matrix: Drinking Water

Lab Sample ID: J61126-33

Collected By: KB-Client

Collection Date: 09/22/2016 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0048	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0821

Client Sample ID: P-73 Room 119 Bathroom Sink

Sample Matrix: Drinking Water

Lab Sample ID: J61126-34

Collected By: KB-Client

Collection Date: 09/22/2016 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0073	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0821

Client Sample ID: P-74 Boys Bathroom 1st Floor

Sample Matrix: Drinking Water

Lab Sample ID: J61126-35

Collected By: KB-Client

Collection Date: 09/22/2016 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0061	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0824

Client Sample ID: P-75 Drinking Fountain by Room 119

Sample Matrix: Drinking Water

Lab Sample ID: J61126-36

Collected By: KB-Client

Collection Date: 09/22/2016 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0824

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level

MDL: Minimum Detection Limit

RL: Reporting Limit

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 9 of 15



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611126

**Project Requested Certification(s)**

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

PA DEP ID: 68-04863

New York State Department of Health

New York State Department of Health

Pennsylvania Department of Environmental Protection

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

*Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

**Reviewed and Approved By:**

Michael Fifield  
Division Manager  
michael.fifield@microbac.com  
10/26/2016 22:20

3021 Buck Drive  
Cortland NY 13045  
Phone: (607) 763-3409 Fax: (607) 763-3416  
NY #10765, EPA #NY00086

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ESCSD							Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Address:	Parker Elem							Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Contact:	Bob Martin							Sample Temp:	12/15
Phone:								Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Project:	Parker Elem							Pickup:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Quote ID:								Dropoff:	G W
Rush TAT Bus. Days: <2 2-5 6-7 7-10								Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Release to DOH: Yes <input checked="" type="checkbox"/>								Container Material:	
Email Results: Yes <input checked="" type="checkbox"/>								Container Size (in ml)	
Fax Results: Yes <input checked="" type="checkbox"/>								Preservative	
Sample Information				Matrix		Number of Containers for Analysis Requested		Commercial/Field Data	
Description/Location	Date	Time	Initial	Type					
1 P-40 Men's Office	9/22/14	6:00 AM	KD	DW					
2 -41 Men's Office		6:00 AM	KD						
3 -42 Men's Office		6:00 AM	KD						
4 -43 Sink per floor		6:11 AM	KD						
5 -44 Drinking Fountain		6:14 AM	KD						
6 -45 Room 109		6:14 AM	KD						
7 -46 Room 111		6:15 AM	KD						
8 -47 Room 111A		6:17 AM	KD						
Print Name and Company					Signature	Date/Time	Comments		
Sampled: Kelt Begun Cortland City Schools					[Signature]	9/22/14 7:05 AM			
Received: Bob Martin ESCSD					[Signature]	9/22/14 1:07			
Received: Eric D'Amico Microbac					[Signature]	9/22/14 1:31			
Received:									
Received:									
Received:									



J611126

3021 Buck Drive  
Cortland NY 13045  
Phone: (607) 763-3409 Fax: (607) 763-3416  
NY #10765, EPA #NY00936

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD							Ice:	YES NO
Address:	Parker Elem							Cooler:	YES NO
Contact:								Sample Temp:	
Phone:								Cooler Seal:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days:	<2 2-6 6-7 7-10							Accepted?	YES NO
Release to DOH:	Yes							Container Material:	
Email Results:	Yes							Container Size (in Ml)	
Fax Results:	Yes							Preservative	
Sample Information				Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type				
1 P- 48 Run 108 Sink	9/22/14	6:00A	KL		DW				
2 - 49 Run 109 Bottom Sink		6:10A	KL						
3 - 50 Drinky Fenton Pyrum 108		6:21A	KL						
4 - 51 Run 130 Sink		6:23A	KL						
5 - 52 Run 130 Drinky Fenton		6:23A	KL						
6 - 53 Run 110 Bottom Sink		6:23A	KL						
7 - 54 Run 132 Sink		6:24A	KL						
8 - 55 Run 132 Drinky Fenton		6:28A	KL						
Print Name and Company						Signature		Date/Time	
Sampled: Keri Orpin Cortland City Sewer						[Signature]		9/22/14 7:55A	
Received: BOB MARTIN CFS&SO						[Signature]		9/22/14 1:05	
Received: Edie Monson Microbac						[Signature]		9/22/14 1:21	
Received:									
Received:									
Received:									



3021 Buick Drive  
Carland NY 13045  
Phone: (607) 763-3409 Fax: (607) 763-3415  
NY #10795, EPA NY00056

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD							Ice:	YES NO
Address:	Parker Elem							Cooler:	YES NO
Contact:								Sample Temp:	
Phone:								Cooler Seat:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days: <2 2-5 6-7 7-10								Accepted?	YES NO
Release to DOH: (Yes)								Container Material	
Email Results: (Yes) <i>Rmartin@cortlandschools.org</i>								Container Size (in ml)	
Fax Results: (Yes) <i>Kwaddy@cortlandschools.org</i>								Preservative	
Sample Information				Number of Containers for Analysis Requested				Common/Field Data	
Description/Location	Date	Time	Initial	Matrix	Type				
1 P-56 Run 132 Run 132 S/L	6/22/14	6:20A	KD	DW					
2 -57 Run 111B Run 111B S/L		6:32A	KD						
3 -58 Run 111F Run 111F S/L		6:34A	KD						
4 -59 Run 111D Run 111D S/L		6:35A	KD						
5 -60 Run 120 Run 120 S/L		6:38A	KD						
6 -61 Drinking Water		6:39A	KD						
7 -62 Run 120 Run 120 S/L		6:39A	KD						
8 -63 Run 121 Run 121 S/L		6:41A	KD						
Print Name and Company				Signature		Date/Time		Comments	
Sampled: Keith Dwyer Cortland City Sch's				<i>Keith Dwyer</i>		6/22/14 7:42A			
Received: Bob Mousier CS&SD				<i>Bob Mousier</i>		6/22/14 1:15P			
Received: Eric Mousier Microbac				<i>Eric Mousier</i>		6/22/14 1:51P			
Received:									
Received:									
Received:									

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD							Ice:	YES NO
Address:	Parker Elem							Cooler:	YES NO
Contact:								Sample Temp:	
Phone:								Cooler Sent:	YES NO
Project:								Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days:	<2	2-5	6-7	7-10				Accepted?	YES NO
Roller to DOH: Yes								Container Material	
Email Results: Yes	Rmartin@cortlandschools.org							Container Size (in Mi)	
Fax Results: Yes	Kwaddy@cortlandschools.org							Preservative	
Sample Information				Number of Containers for Analysis Requested		Comments		Commercial/Field Data	
Description/Location	Date	Time	Initial	Matrix	Type				
1 P-64 Run 121 Dryly Fork	6/22/16	6:41A	KJ	DW					
2 -65 Run 121 Bottom Sink		6:41A	KJ						
3 -64 Run 115 Sink		6:41A	KJ						
4 -67 Run 115 Dryly Fork		6:47A	KJ						
5 -68 Run 115 Bottom Sink		6:47A	KJ						
6 -69 Run 117 Sink		6:49A	KJ						
7 -70 Run 117 Bottom Sink		6:50A	KJ						
8 -71 Run 119 Sink		6:53A	KJ						
Print Name and Company				Signature		Date/Time			
Sampled: Ken Bryn Cortland City Sch's				[Signature]		6/24/16 7:05A			
Received: Bob Martin CFS-50				[Signature]		6/24/16 1:05P			
Received: Eric Monson Microbac				[Signature]		6/24/16 1:34P			
Received:									
Received:									
Received:									

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD					Ice:	YES NO		
Address:	Parker Elem					Cooler:	YES NO		
Contact:						Sample Temp:			
Phone:						Cooler Seal:	YES NO		
Project:						Pickup:	YES NO		
Quote ID:						Dropoff:	C W		
Rush TAT Bus. Days:	<2 2-5 5-7 7-10					Accepted?	YES NO		
Release to DOH:	Yes					Container Material			
Email Results:	Yes					Container Size (in ml)			
Fax Results:	Yes					Preservative			
Sample Information				Comments		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested			
1 P-72 Run 119	9/22/14	6:57A	KG		DW	1			
2 -73 Run 115		6:57A	KG						
3 -74 Run 116		6:57A	KG						
4 -75 Run 117		6:57A	KG						
5 -76 Run 118		6:57A	KG						
6 -77 Run 119		6:57A	KG						
7 -78 Run 120		6:57A	KG						
8 -79 Run 121		6:57A	KG						
Print Name and Company						Signature		Date/Time	
Sampled: Ken Dwyer Cortland City Sch's						[Signature]		9/24/14 7:00A	
Received: B.B. Minton ECSD						[Signature]		9/24/14 1:15P	
Received: Eric Minton Microbac						[Signature]		9/24/14 1:34P	
Received:									
Received:									
Received:									