

Cortland Enlarged City School District Lead Testing

Smith Elem.	99	99	25	Room 300 Hand Wash Sink	Older faucet (Replace & Retest)
				Room 300 Sink 1	Sink 2 test ok next to Sink 1, earlier tested was ok (Replace & Retest)
				Room 310 Bath Sink	Older faucet (Replace & Retest)
				Room 360 Bath & Room Sinks	Older faucet (Replace & Retest)
				Room 370 Sink, Older Dental Sink	Older Dental Sink (Remove fixture)
				Room 400A Bath Sink	Newer faucet, reading not that high (Retest)
				Room 502 Room Sink	Drinking Fountain on one side & Bath Sink on the other side of Room Sink tested low, all new fixtures, doesn't make sense Room Sink testing about five times what other two tested (Retest)
				Room 504 Bath Sink	Older faucet, flow issue, faucet is not use & water is off (Replace & Retest)
				Room 20 Bath room sink	Older faucet (Replace & Retest)
				Room 20 class sink	Older faucet (Replace & Retest)

Cortland Enlarged City School District Lead Testing

				Room 30 class sink	Older faucet (Replace & Retest)
				Room 40 bath room sink	Older faucet (Replace & Retest)
				Room 40 class sink	Older faucet (Replace & Retest)
				Room 26 class sink	Older faucet (Replace & Retest)
				Room 27 drinking fountain	Replace and retest
				Room 130 class sink	Older faucet (Replace & Retest)
				Room 120 class sink	Older faucet (Replace & Retest)
				Room 150 bath room sink	Older faucet (Replace & Retest)
				Room 160 bath room sink	Older faucet (Replace & Retest)
				Room 170 bath room sink	Older faucet (Replace & Retest)
				Room 180 bath room sink	Older faucet (Replace & Retest)
				Room 190 bath room sink	Older faucet (Replace & Retest)



Cortland Enlarged City School District Lead Testing

				Room 200 bath sink Room 54 Girls locker office bath room	Older faucet (Replace & Retest) Older faucet (Replace & Retest)
--	--	--	--	--	--



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Cortland City School District

Project Name: Smith Elementary School

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/24/2016 13:55
Reported: 11/28/2016 15:26

Analytical Testing Parameters

Client Sample ID: S-1 Room #20 Bath Sink
Lab Sample ID: J6I1106-01
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0346	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1101

Analytical Testing Parameters

Client Sample ID: S-2 Room #20 Class Sink
Lab Sample ID: J6I1106-02
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0155	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1102

Analytical Testing Parameters

Client Sample ID: S-3 Room #20 Drinking Fountain
Lab Sample ID: J6I1106-03
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0135	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1102

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Page 1 of 29



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-4 Room #30 Bath Sink
Lab Sample ID: J6I1106-04
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00315	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1103

Analytical Testing Parameters

Client Sample ID: S-5 Room #30 Class Sink
Lab Sample ID: J6I1106-05
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0700	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1104

Analytical Testing Parameters

Client Sample ID: S-6 Room #30 Drinking Fountain
Lab Sample ID: J6I1106-06
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0128	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1106



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-7 Room #40 Bath Sink
Lab Sample ID: J6I1106-07
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0590	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1106

Analytical Testing Parameters

Client Sample ID: S-8 Room #40 Class Sink
Lab Sample ID: J6I1106-08
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0213	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1107

Analytical Testing Parameters

Client Sample ID: S-9 Room #40 Drinking Fountain
Lab Sample ID: J6I1106-09
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00724	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1109



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-10 Room #50 Bath Sink
Lab Sample ID: J6I1106-10
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0101	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1110

Analytical Testing Parameters

Client Sample ID: S-11 Room #50 Class Sink
Lab Sample ID: J6I1106-11
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0123	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1110

Analytical Testing Parameters

Client Sample ID: S-12 Room #50 Drinking Fountain
Lab Sample ID: J6I1106-12
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0101	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1111



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-13 Room #60 Bath Sink
Lab Sample ID: J6I1106-13
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00657	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1112

Analytical Testing Parameters

Client Sample ID: S-14 Room #60 Class Sink
Lab Sample ID: J6I1106-14
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0117	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1112

Analytical Testing Parameters

Client Sample ID: S-15 Room #60 Drinking Fountain
Lab Sample ID: J6I1106-15
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00443	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1113



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-16 Room #90 Bath Sink
Lab Sample ID: J6I1106-16
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00774	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1115

Analytical Testing Parameters

Client Sample ID: S-17 Room #90 Class Sink
Lab Sample ID: J6I1106-17
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0106	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1117

Analytical Testing Parameters

Client Sample ID: S-18 Room #90 Drinking Fountain
Lab Sample ID: J6I1106-18
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00457	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1118



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-19 Room #100 Bath Sink
Lab Sample ID: J6I1106-19
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0111	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1118

Analytical Testing Parameters

Client Sample ID: S-20 Room #100 Class Sink
Lab Sample ID: J6I1106-20
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0140	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1119

Analytical Testing Parameters

Client Sample ID: S-21 Room #100 Drinking Fountain
Lab Sample ID: J6I1106-21
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00538	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1120



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-22 Room #110 Bath Sink
Lab Sample ID: J6I1106-22
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00639	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1120

Analytical Testing Parameters

Client Sample ID: S-23 Room #110 Class Sink
Lab Sample ID: J6I1106-23
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00462	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1121

Analytical Testing Parameters

Client Sample ID: S-24 Room #110 Drinking Fountain
Lab Sample ID: J6I1106-24
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00243	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1122



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-25 Room #120 Bath Sink
Lab Sample ID: J6I1106-25
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00308	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1122

Analytical Testing Parameters

Client Sample ID: S-26 Room #120 Class Sink
Lab Sample ID: J6I1106-26
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.156	0.0150	0.00100	mg/L	GE	10/27/16 0800	11/01/16 1126

Analytical Testing Parameters

Client Sample ID: S-27 Room #120 Drinking Fountain
Lab Sample ID: J6I1106-27
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0154	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1126



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-28 Room #130 Bath Sink
Lab Sample ID: J6I1106-28
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 08:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0118	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1127

Analytical Testing Parameters

Client Sample ID: S-29 Room #130 Class Sink (1)
Lab Sample ID: J6I1106-29
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 08:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0286	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1128

Analytical Testing Parameters

Client Sample ID: S-30 Room #130 Class Sink (2)
Lab Sample ID: J6I1106-30
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 08:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0198	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1128



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-31 Room #130 Drinking Fountain
Lab Sample ID: J6I1106-31
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 08:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00812	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1129

Analytical Testing Parameters

Client Sample ID: S-32 Room #150 Bath Sink
Lab Sample ID: J6I1106-32
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0220	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1130

Analytical Testing Parameters

Client Sample ID: S-33 Room #150 Class Sink
Lab Sample ID: J6I1106-33
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00197	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1130



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-34 Room #150 Drinking Fountain
Lab Sample ID: J6I1106-34
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00191	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1131

Analytical Testing Parameters

Client Sample ID: S-35 Room #160 Bath Sink
Lab Sample ID: J6I1106-35
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0153	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1133

Analytical Testing Parameters

Client Sample ID: S-36 Room #160 Class Sink
Lab Sample ID: J6I1106-36
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00386	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1135



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-37 Room #160 Drinking Fountain
Lab Sample ID: J6I1106-37
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00674	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1136

Analytical Testing Parameters

Client Sample ID: S-38 Room #170 Bath Sink
Lab Sample ID: J6I1106-38
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0171	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1137

Analytical Testing Parameters

Client Sample ID: S-39 Room #170 Class Sink
Lab Sample ID: J6I1106-39
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00394	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1137



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-40 Room #170 Drinking Fountain
Lab Sample ID: J6I1106-40
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00302	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1138

Analytical Testing Parameters

Client Sample ID: S-41 Room #180 Bath Sink
Lab Sample ID: J6I1106-41
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0156	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1139

Analytical Testing Parameters

Client Sample ID: S-42 Room #180 Class Sink
Lab Sample ID: J6I1106-42
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00677	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1139



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-43 Room #180 Drinking Fountain
Lab Sample ID: J6I1106-43
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00384	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1141

Analytical Testing Parameters

Client Sample ID: S-44 Room #190 Bath Sink
Lab Sample ID: J6I1106-44
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0171	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1142

Analytical Testing Parameters

Client Sample ID: S-45 Room #190 Class Sink
Lab Sample ID: J6I1106-45
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00452	0.0150	0.00100	mg/L		10/27/16 0800	11/03/16 1114



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-46 Room #190 Class Sink (2)
Lab Sample ID: J6I1106-46
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00482	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1145

Analytical Testing Parameters

Client Sample ID: S-47 Room #190 Drinking Fountain
Lab Sample ID: J6I1106-47
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00429	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1145

Analytical Testing Parameters

Client Sample ID: S-48 Room #200 Bath Sink
Lab Sample ID: J6I1106-48
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0227	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1146



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-49 Room #200 Class Sink
Lab Sample ID: J6I1106-49
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00490	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1147

Analytical Testing Parameters

Client Sample ID: S-50 Room #200 Drinking Fountain
Lab Sample ID: J6I1106-50
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00241	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1147

Analytical Testing Parameters

Client Sample ID: S-51 West Hall Drinking Fountain
Lab Sample ID: J6I1106-51
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0113	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1149



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-52 Room #220 Sink
Lab Sample ID: J6I1106-52
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0436	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1150

Analytical Testing Parameters

Client Sample ID: S-53 North Hall Drinking Fountain
Lab Sample ID: J6I1106-53
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00424	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1151

Analytical Testing Parameters

Client Sample ID: S-54 Girls Locker Office Bathroom
Lab Sample ID: J6I1106-54
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0227	0.0150	0.00100	mg/L	G	10/27/16 0800	11/01/16 1151



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-55 Girls Locker Sink (1)
Lab Sample ID: J6I1106-55
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00694	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1152

Analytical Testing Parameters

Client Sample ID: S-56 Girls Locker Sink (2)
Lab Sample ID: J6I1106-56
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00916	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1154

Analytical Testing Parameters

Client Sample ID: S-57 Boys Locker Sink
Lab Sample ID: J6I1106-57
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0112	0.0150	0.00100	mg/L		11/16/16 2127	11/21/16 1511



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1106

Analytical Testing Parameters

Client Sample ID: S-58 Room #270 Class Sink
Lab Sample ID: J6I1106-58
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00960	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1155

Analytical Testing Parameters

Client Sample ID: S-59 Room #270 Class Sink (2)
Lab Sample ID: J6I1106-59
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: N/A

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0148	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1155

Analytical Testing Parameters

Client Sample ID: S-60 Room #270 Drinking Fountain
Lab Sample ID: J6I1106-60
Sample Type: Grab

Collected By: DP-Client
Collection Date: 09/21/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00243	0.0150	0.00100	mg/L		10/27/16 0800	11/01/16 1157

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
E: Estimated result
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611106

Cooler Receipt Log

Cooler ID: Default Cooler

Temp: 26.1°C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	No	Containers Intact	No
COC/Labels Agree	No	Preservation Correct (or not required)	No
Received on Ice (or not required)	No		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

New York State Department of Health

PA DEP ID: 68-04863

Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Renee Lantz For Michael Fifield

Division Manager

11/28/2016 15:26

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:			
Name: COZTLAND E.C.S.D							
Address: SMITH SCHOOL							
23 WHEELER AVE							
Contact:							
Phone:							
Project: Smith							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes							
Fax Results: Yes							
Sample Information							
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	
1 ROOM #20 BATH SINK	9/20/16	6:41AM	DF	DW			
2 ROOM #20 CLASS SINK	9/20/16	6:44AM	DF				
3 ROOM #20 DRINKING FOUNTAIN	9/20/16	6:46AM	DF				
4 ROOM #30 BATH SINK	9/20/16	6:50AM	DF				
5 ROOM #30 CLASS SINK	9/20/16	6:52AM	DF				
6 ROOM #30 DRINKING FOUNTAIN	9/20/16	6:55AM	DF				
7 ROOM #40 BATH SINK	9/20/16	6:59AM	DF				
8 ROOM #40 CLASS SINK	9/20/16	7:00AM	DF				
Print Name and Company							
Sampled: DAVID PAYNE SMITH SCHOOL							
Received: BOB MARTIN / C.E.S.D							
Received: Jennifer Walker MTS							
Received:							
Received:							
Received:							

Receiving Info (Lab Use Only)		Comments	
Ice:	YES ☒ NO ☐		
Cooler:	YES ☒ NO ☐		
Sample Temp:	26.1		
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES ☒ NO ☐		
Container Material			
Container Size (in ml)			
Preservative			
Comments/Fla			

J611106

3021 Buck Drive
Cortland NY 13046
Phone: (607) 763-3403 Fax: (607) 763-3416
NY #10706, EPA #NY00086

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	CORTLAND E.C.S.D						Ice:	YES NO
Address:	SMITH SCHOOL						Cooler:	YES NO
	33 WHITELEAF AVE						Sample Temp:	
Contact:							Cooler Serial:	YES NO
Phone:							Pickup:	YES NO
Project:							Dropoff:	C W
Quote ID:	PO#:						Accepted?	YES NO
Rush TAT Bus. Days: <2 2-5 6-7 7-10	Date Req.:						Container Material	
Release to DOH: Yes							Container Size (in Mi)	
Email Results: Yes							Preservative	
Fax Results: Yes							Comments/Field Data	
Sample Information								
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested			
1 Room #40 DRINKING FOUNTAIN	9/20/16	7:02AM	RB	DW	1			
2 Room #50 BATH SINK	9/20/16	7:02AM	RB					
3 Room #50 CLASS SINK	9/20/16	7:02AM	RB					
4 Room #50 DRINKING FOUNTAIN	9/20/16	7:10AM	RB					
5 Room #60 BATH SINK	9/20/16	7:14AM	RB					
6 Room #60 CLASS SINK	9/20/16	7:16AM	RB					
7 Room #60 DRINKING FOUNTAIN	9/20/16	7:18AM	RB					
8 Room #90 BATH SINK	9/20/16	7:21AM	RB					
Plant Name and Company					Signature			
Sampled: DAVID PAYNE SMITH SCHOOL					Date/Time: 9/20/16 8:35AM			
Revised: BOB MARTIN C.E.S.D					Date/Time: 9/20/16 8:35			
Revised: Jennifer Walker MTS					Date/Time: 9/20/16 1355			
Revised:								
Revised:								
Revised:								

3021 Brook Drive
Cortland NY 13848
Phone: (607) 763-3408 Fax: (607) 763-3415
NY #10705, EPA #NY000896

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:		MNY Workorder #	
Name: CORTLAND E.C.S.D							
Address: SMITH SCHOOL							
33 WHEELER AVE							
Contact:							
Phone:							
Project:							
Quote ID:				PO#:			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes							
Fax Results: Yes							
Sample Information							
Description/Location	Date	Time	Initial	Matrix	Type	Analysis Requested	
1 Room # 70 CLASS SINK	9/20/16	7:22 AM	DB	DW			
2 Room # 90 DRINKING FOUNTAIN	9/20/16	7:14 AM	DB				
3 Room # 100 BATH SINK	9/20/16	7:27 AM	DB				
4 Room # 100 CLASS SINK	9/20/16	7:19 AM	DB				
5 Room # 100 DRINKING FOUNTAIN	9/20/16	7:31 AM	DB				
6 Room # 116 BATH SINK	9/20/16	7:37 AM	DB				
7 Room # 110 CLASS SINK	9/20/16	7:30 AM	DB				
8 Room # 110 DRINKING FOUNTAIN	9/20/16	7:39 AM	DB				
Signature: DAVID PAYNE SMITH SCHOOL				Date/Time: 9/21/16 8:35 AM			
Signature: BOB MORGAN C.F.C.S.D				Date/Time: 9/21/16 1:35			
Signature: Jennifer Walker MTS Jennings Walker				Date/Time: 9/21/16 1:35			
Signature:				Date/Time:			
Signature:				Date/Time:			
Signature:				Date/Time:			
Signature:				Date/Time:			
Signature:				Date/Time:			

3821 Buck Drive
Corland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10705, EPA #NY00836

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

Client Information				Billing/Invoice:				MINY Workorder #			
Name: CORLAND E.C.S.D.								Receiving Info (Lab Use Only)			
Address: SMITH SCHOOL								Ice: YES NO			
33 WHEELER AVE								Cooler: YES NO			
Contact:								Sample Temp:			
Phone:								Cooler Seal: YES NO			
Project:								Pickup: YES NO			
Quote ID:								Dropoff: C W			
Rush TAT Bus. Days: <2 2-6 6-7 7-10				Date Req.:				Accepted? YES NO			
Releap to DOH: Yes								Container Material			
Email Results: Yes								Container Size (in Ml)			
Fax Results: Yes								Preservative			
Sample Information				Number of Containers for Analysis Requested				Comments			
Description/Location	Date	Time	Initial	Matrix Type							
1 ROOM #120 BATH SINK	9/20/16	7:51 AM	DL	DW	1						
2 ROOM #120 CLASS SINK	9/20/16	7:53 AM	DL								
3 ROOM #120 DRINKING FOUNT.	9/20/16	7:54 AM	DL								
4 ROOM #130 BATH SINK	9/20/16	8:01 AM	DL								
5 ROOM #130 CLASS SINK	9/20/16	8:02 AM	DL								
6 ROOM #130 CLASS SINK (2)	9/20/16	8:03 AM	DL								
7 ROOM #130 DRINKING FOUNT.	9/20/16	8:04 AM	DL								
8											

Print Name and Company	Signature	Date/Time	Comments
DAVID PAYNE SMITH SCHOOL	<i>[Signature]</i>	9/20/16 8:25	
BEB MARTIN CRESS	<i>[Signature]</i>	9/20/16 8:37	
Jennifer Waller Mt	<i>[Signature]</i>	9/20/16 1355	

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: CORTLAND E.C.S.D												Ice: YES NO			
Address: SMITH SCHOOL												Cooler: YES NO			
33 WHEELER AVE												Sample Temp:			
Contact:												Cooler Seal: YES NO			
Phone:												Pickup: YES NO			
Project:												Dropoff: C W			
Quote ID:				PO#:								Accepted? YES NO			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:								Container Material			
Release to DOH: Yes												Container Size (in M)			
Email Results: Yes												Preservative			
Fax Results: Yes												Comments/Field Data			
Sample Information				Matrix				Number of Containers for Analysis Requested							
Description/Location	Date	Time	Initial	Type											
1 Room#150 BATH SINK	9/24/14	6:15AM	DL	DW	1										
2 Room#150 CLASS SINK	9/24/14	6:14AM	DL												
3 Rm#150 DRINKING FOUNT	9/24/14	6:15AM	DL												
4 Room#160 BATH SINK	9/24/14	6:18AM	DL												
5 Room#160 CLASS SINK	9/24/14	6:19AM	DL												
6 Room#160 DRINKING FOUNT	9/24/14	6:20AM	DL												
7 Room#170 BATH SINK	9/24/14	6:20AM	DL												
8 Room#170 CLASS SINK	9/24/14	6:19AM	DL												
Print Name and Company				Signature				Date/Time				Comments			
Sampled: DAVID PAYNE SMITH SCHOOL				[Signature]				9/24/14 8:35 AM							
Received: BOB MONTANA C.E.O.				[Signature]				9/24/14 8:37							
Received: Jennifer Walker msh				[Signature]				9/24/14 1355							
Received:															
Received:															
Received:															

3824 Buck Drive
 Corland NY 13046
 Phone: (607) 763-3408 Fax: (607) 763-3415
 NY #10705, EPA #NY100926

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: COETLAND E.C.S.D								Ice: YES NO	
Address: SMITH SCHOOL								Cooler: YES NO	
33 WHEELER AVE.								Sample Temp:	
Contact:								Cooler Seal: YES NO	
Phone:								Pickup: YES NO	
Project:								Dropoff: C W	
Quote ID:				PO#:				Accepted? YES NO	
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:				Container Material	
Release to DOH: Yes								Container Size (in Ml)	
Email Results: Yes								Preservative	
Fax Results: Yes								Comments/Field Data	
Sample Information									
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested			
1 Room #170 DRINKING FONT	9/21/14	6:30 AM	DL	DW		1			
2 Room #180 BATH SINK	9/21/14	6:35 AM	DL						
3 Room #180 CLASS SINK	9/21/14	6:36 AM	DL						
4 Room #180 DRINKING FONT	9/21/14	6:37 AM	DL						
5 Room #190 BATH SINK	9/21/14	6:41 AM	DL						
6 Room #190 CLASS SINK	9/21/14	6:42 AM	DL						
7 Room #190 CLASS SINK (2)	9/21/14	6:42 AM	DL						
8 Room #190 CLASS SINK	9/21/14	6:43 AM	DL						
9 Room #190 DRINKING FONT	9/21/14	6:44 AM	DL						
Signature: <i>[Signature]</i>						Date/Time: 9/21/14 8:35			
Print Name and Company: DAVID PAYNE SMITH SCHOOL						Comments:			
Collected: <i>[Signature]</i>						9/21/14 8:35			
Collected: <i>[Signature]</i>						9/21/14 8:35			
Collected: <i>[Signature]</i>						9/21/14 1355			
Collected:									
Collected:									

3024 Duck Drive
Cortland NY 13046
Phone: (607) 763-3409 Fax: (607) 763-3416
NY #10706, EPA #NY00035

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:		Analyte Requested		Receiving Info (Lab Use Only)	
Name: CORTLAND E.C.S.D								Ice:	YES NO
Address: SMITH SCHOOL								Cooler:	YES NO
33 WHEGGER AVE								Sample Temp:	
Contact:								Cooler Seal:	YES NO
Phone:								Pickup:	YES NO
Project:								Dropoff:	C W
Quote ID:				POB:				Accepted?	YES NO
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Data Req.:				Container Material:	
Release to DOH: Yes								Container Size (in Ml)	
Email Results: Yes								Preservative	
Fax Results: Yes								Comments/Field Data	
Sample Information				Matrix		Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Type					
1 Room # 200 Bath Sink	9/21/16	6:11 AM	DL	DW	1				
2 Room # 200 CLING Sink	9/21/16	6:47 AM	DL		1				
3 Room # 200 DRINKING FOUNT	9/21/16	6:48 AM	DL		1				
4 WEST HALL DRINKING FOUNT	9/21/16	6:50 AM	DL		1				
5 Room # 200 Sink	9/21/16	6:52 AM	DL		1				
6 NORTH HALL DRINKING FOUNT	9/21/16	6:54 AM	DL		1				
7 GIRLS LOCKER OFFICE BATH	9/21/16	6:54 AM	DL		1				
8 GIRLS LOCKER SINK (1)	9/21/16	6:58 AM	DL		1				
Print Name and Company				Signature		Date/Time		Comments	
DAVID PAYNE SMITH SCHOOL				[Signature]		9/20/16 8:35 AM			
BOB MERTON C.E.S.D.				[Signature]		9/20/16 8:37			
JENNIFER WALKER Mrs				[Signature]		9/20/16 1355			
JENNIFER WALKER Mrs				[Signature]					
JENNIFER WALKER Mrs				[Signature]					
JENNIFER WALKER Mrs				[Signature]					
JENNIFER WALKER Mrs				[Signature]					

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: COETLAND E.C.S.D												Ice: YES NO			
Address: SMITH SCHOOL												Cooler: YES NO			
33 WHEELER AVE												Sample Temp:			
Contact:												Cooler Seal: YES NO			
Phone:												Pickup: YES NO			
Project:												Dropoff: C W			
Quote ID:				PO#:								Accepted? YES NO			
Rush TAT Bus. Days: <2 2-5 6-7 7-10				Date Req.:								(Container Material)			
Release to DOH: Yes												Container Size (in Ml)			
Email Results: Yes												Preservative			
Fax Results: Yes												Comments/Field Data			
Sample Information								Number of Containers for Analysis Requested							
Description/Location	Date	Time	Initial	Matrix Type											
1 S-57 GIRLS LOCKER SINK (2)	9/21/14	6:59PM	DB	DW											
2 S-57 BOYS LOCKER SINK	9/21/14	7:01AM	DB												
3 S-58 ROOM #270 CLASS SINK	9/21/14	7:30AM	DB												
4 S-59 ROOM #270 CLASS SINK	9/21/14	7:35AM	DB												
5 S-60 ROOM #270 DRINKING FONT	9/21/14	7:06AM	DB												
6															
7															
8															

Print Name and Company	Signature	Date/Time	Comments
Sampled: DAVID PAYNE SMITH SCHOOL	<i>[Signature]</i>	9/21/14 8:35	
Received: BIR MARTIN OBOGO	<i>[Signature]</i>	9/21/14 8:37	
Received: Jennifer Waller	<i>[Signature]</i>	9/21/14 1355	
Received:			
Received:			