



Cortland Enlarged City School District Lead Testing

Building	# of Samples Submitted	# of Results Received	# of Samples Above 15 ppb.	Location	Remediation
Parker Elem.	75	75	4	Room 111F sink Room 111D sink Room 121 sink Room 117	Replace and retest Replace and retest Replace and retest Replace and retest



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Cortland City School District

Project Name: Parker Elementary School

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/21/2016
Reported: 10/19/2016

Analytical Testing Parameters

Client Sample ID: P-1 Room 201 Bathroom
Sample Matrix: Drinking Water
Lab Sample ID: J611104-01

Collected By: KB-Client
Collection Date: 09/21/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1443

Client Sample ID: P-2 Room 201 Drinking Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J611104-02

Collected By: KB-Client
Collection Date: 09/21/2016 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1443

Client Sample ID: P-3 Room 202 Bathroom
Sample Matrix: Drinking Water
Lab Sample ID: J611104-03

Collected By: KB-Client
Collection Date: 09/21/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0042	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1444

Client Sample ID: P-4 Room 202 Drinking Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J611104-04

Collected By: KB-Client
Collection Date: 09/21/2016 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1445

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-5 Room 203 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:18
Lab Sample ID: J611104-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1447

Client Sample ID: P-6 2nd Floor Boys Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:19
Lab Sample ID: J611104-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.012	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1449

Client Sample ID: P-7 Room 208 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:22
Lab Sample ID: J611104-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0032	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1449

Client Sample ID: P-8 Room 208 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:22
Lab Sample ID: J611104-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1450



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61104

Client Sample ID:	P-9 Room 205 Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:25
Lab Sample ID:	J61104-09		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0026	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1451

Client Sample ID:	P-10 Room 205 Drinking Fountain	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:25
Lab Sample ID:	J61104-10		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0031	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1451

Client Sample ID:	P-11 Room 210 Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:29
Lab Sample ID:	J61104-11		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0019	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1452

Client Sample ID:	P-12 Room 219 Drinking Fountain	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:29
Lab Sample ID:	J61104-12		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0019	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1453



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-13 Room 207 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:31
Lab Sample ID: J611104-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0067	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1455

Client Sample ID: P-14 Room 207 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:31
Lab Sample ID: J611104-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0066	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1455

Client Sample ID: P-15 Room 209 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:34
Lab Sample ID: J611104-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1456

Client Sample ID: P-16 Room 209 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:34
Lab Sample ID: J611104-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1458



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61104

Client Sample ID: P-17 2nd Floor Staff Bathroom	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:38
Lab Sample ID: J61104-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0030	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1458

Client Sample ID: P-18 Room 230 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:41
Lab Sample ID: J61104-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0014	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1459

Client Sample ID: P-19 Room 230 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:41
Lab Sample ID: J61104-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0013	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1500

Client Sample ID: P-20 Room 230 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:41
Lab Sample ID: J61104-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0073	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1500



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61104

Client Sample ID:	P-21 Room 232 Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:45
Lab Sample ID:	J61104-21		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0024	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1502

Client Sample ID:	P-22 Room 232 Drinking Fountain	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:45
Lab Sample ID:	J61104-22		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0016	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1503

Client Sample ID:	P-23 Room 232 Bathroom Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:45
Lab Sample ID:	J61104-23		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/07/16 0817	10/10/16 1539

Client Sample ID:	P-24 2nd Floor Girls Bathroom	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/21/2016 6:48
Lab Sample ID:	J61104-24		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0075	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1504



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-25 Room 220 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:51
Lab Sample ID: J611104-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1504

Client Sample ID: P-26 Room 220 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:51
Lab Sample ID: J611104-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1506

Client Sample ID: P-27 Room 220 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:51
Lab Sample ID: J611104-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1507

Client Sample ID: P-28 Room 221 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:55
Lab Sample ID: J611104-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0044	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1508



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611104

Client Sample ID: P-29 Room 221 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:55
Lab Sample ID: J611104-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.013	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1508

Client Sample ID: P-30 Room 221 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:55
Lab Sample ID: J611104-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1510

Client Sample ID: P-31 Room 211 Sink on Left	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:59
Lab Sample ID: J611104-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0076	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1511

Client Sample ID: P-32 Room 211 Sink on Right	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 6:59
Lab Sample ID: J611104-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1512



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-33 Room 213 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:02
Lab Sample ID: J6I1104-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0054	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1512

Client Sample ID: P-34 Room 213 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:02
Lab Sample ID: J6I1104-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0036	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1513

Client Sample ID: P-35 Room 215 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:05
Lab Sample ID: J6I1104-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0047	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1514

Client Sample ID: P-36 Room 215 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:05
Lab Sample ID: J6I1104-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0046	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1516



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Client Sample ID: P-37 Room 216 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:07
Lab Sample ID: J6I1104-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0089	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1516

Client Sample ID: P-38 Room 216 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:07
Lab Sample ID: J6I1104-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.011	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1518

Client Sample ID: P-39 Drinking Fountain in Hallway by Room 214	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/21/2016 7:10
Lab Sample ID: J6I1104-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0017	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1519

Laboratory
 NY: Microbac Laboratories, Inc., New York Division

Definitions
 AL: Action Level
 MDL: Minimum Detection Limit
 RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 PA DEP ID: 68-04863	New York State Department of Health Pennsylvania Department of Environmental Protection



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1104

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "Christine Pechacek".

Christine Pechacek For Michael Fifield
Division Manager
michael.fifield@microbac.com
10/19/2016 12:24

3021 Buck Drive
 Cortland NY 13005
 Phone: (607) 763-3008 Fax: (607) 768-9415
 NY #10795, EPA #NY00856

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)					
Name:	Cortland ECSD		Address:	Parker Etern		Project:			Ice:	YES	NO	COoler:	YES	NO
Contact:			Phone:			Quote ID:			Sample Temp:			COoler Seal:	YES	NO
PO#:			Rush TAT Bns. Days:	2-5 5-7 7-10		Date Req.:			Pickup:	YES	NO	Dropoff:	C	W
Release to DOH:	<input checked="" type="checkbox"/>		Email Results:	<input checked="" type="checkbox"/>		PO#:			Accepted?	YES	NO	Container Material:		
Print Results:	<input checked="" type="checkbox"/>		Print Results:	<input checked="" type="checkbox"/>		PO#:			Container Size (in Mil)			Preservative:		
Email: Rmartin@cortlandschools.org Fax: Kvaldy@cortlandschools.org			PO#: Date Req.:			Number of Containers for Analysis Requested			Comments/Field Data					
Sample Information			Matrix			Signature			Date/Time					
Description/Location	Date	Time	Initial	Type	Signature	Date/Time	Comments							
1 P-09 Room 205 Sink	9/21/16	6:55A	KR	DW	[Signature]	9/21/16 7:55AM								
2 -10 Room 205 Drinking Fountain	[Arrow]	6:35A	KR	[Arrow]	[Signature]	9/21/16 12:15P								
3 -11 Room 210 Sink		6:55A	KR											
4 -12 Room 210 Drinking Fountain	[Arrow]	6:25A	KR	[Arrow]	[Signature]	9/21/16 1400								
5 -13 Room 207 Sink		6:35A	KR											
6 -14 Room 207 Drinking Fountain	[Arrow]	6:35A	KR	[Arrow]	[Signature]									
7 -15 Room 209 Sink		6:35A	KR											
8 -16 Room 209 Drinking Fountain		6:35A	KR		[Signature]									

3021 Brook Drive
 Cortland NY 13045
 Phone: (607) 763-3409 Fax: (607) 763-3415
 NY #10705, EPA #NY100836

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: Cortland ECSD				Address: Parker Etern				Contact:				Ice: YES NO			
Phone:				Project:				Quote ID:				Cooler: YES NO			
Rush TAT Bus. Days: < 2-5 5-7 7-10				Date Req.:				PO#: PO#:				Sample Temp: YES NO			
Release to DOH: <input checked="" type="checkbox"/> Yes				Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Cooler Seal: YES NO			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Pickup: YES NO				Dropoff: C W			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Accepted? YES NO				Container Material			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Container Size (in Ml)				Preservative			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Number of Containers for Analysis Requested				Comments			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Signature				Date/Time			
Email Results: <input checked="" type="checkbox"/> Yes				Fax Results: <input checked="" type="checkbox"/> Yes				Print Name and Company				Comments			
Sample Information				Matrix				Type				Number of Containers for Analysis Requested			
Description/Location				Date				Time				Initial			
1 P-25 Run 220 Sink				9/21/16				6:51A				K17			
2 -26 Drinky Fountain				↓				6:51A				K13			
3 -27 Bottom Sink				↓				6:51A				K15			
4 -28 Sink				↓				6:51A				K17			
5 -29 Drinking Fountain				↓				6:55A				K13			
6 -30 Bottom Sink				↓				6:55A				K15			
7 -31 Sink on left				↓				6:59A				K13			
8 -32 Sink on right				↓				6:59A				K17			
Sampled: Keith Byrum Cortland City Schools				Signature: [Signature]				Date/Time: 9/21/16 7:54A				Comments:			
Received: BOB Moxon CACS				Signature: [Signature]				Date/Time: 9/21/16 12:05				Comments:			
Received: Jennifer Walker Mt. Mansfield				Signature: [Signature]				Date/Time: 9/21/16 1400				Comments:			
Received:				Signature:				Date/Time:				Comments:			
Received:				Signature:				Date/Time:				Comments:			

3021 Brook Drive
 Cortland NY 13046
 Phone: (607) 765-2405 Fax: (607) 768-3416
 NY #10705, EPA #NY00895

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoices:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: Cortland ECSD				Project: PO#:				Ice: YES NO				Cooler: YES NO			
Address: Parker Etern				Date Recq: 2-5 5-7 7-10				Sample Temp:				Cooler Seal: YES NO			
Contact:				Rush TAT Bur. Days: < 2-5 5-7 7-10				Pickup: YES NO				Dropoff: G W			
Phone:				Release to DOH: <input checked="" type="checkbox"/>				Accepted? YES NO				Container Material			
Project:				Email Results: <input checked="" type="checkbox"/> <i>pmartin@cortlandschools.org</i>				Container Size (in MI)				Preservative			
Quote ID:				Fax Results: <input checked="" type="checkbox"/> <i>kwatby@cortlandschools.org</i>				Commercial/Field Data							
Sample Information				Matrix				Number of Containers for Analysis Requested							
Description/Location	Date	Time	Initial	Type	Signature	Date/Time	Comments								
1 P-33 Room 213 Sink	6/21/16	7:00 AM	KD	DW	[Signature]	6/21/16 7:15 AM									
2 -34 Room 213 Drinking Fountain		7:00 AM	KD		[Signature]	7/1/16 12:45									
3 -35 Room 213 Sink		7:05 AM	KD		[Signature]	7/1/16 1:00									
4 -36 Room 213 Drinking Fountain		7:05 AM	KD		[Signature]										
5 -37 Room 214 Sink		7:00 AM	KD		[Signature]										
6 -38 Room 214 Drinking Fountain		7:07 AM	KD		[Signature]										
7 -39 Drinking Fountain in Hallway by room 214		7:10 AM	KD		[Signature]										
Print Name and Company				Signature											
Sampled: Kevin Ryan Cortland City School				[Signature]											
Received: Bob Martin OSES				[Signature]											
Received: Jennifer Walker MGE				[Signature]											
Received:															
Received:															



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Cortland City School District

Project Name: Parker Elementary

Neal Helms
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 09/22/2016
Reported: 10/26/2016

Analytical Testing Parameters

Client Sample ID:	P-40 Main Office Bathroom Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:06
Lab Sample ID:	J61126-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0756

Client Sample ID:	P-41 Nurse's Office Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:08
Lab Sample ID:	J61126-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0016	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0756

Client Sample ID:	P-42 Nurse's Office Bathroom Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:08
Lab Sample ID:	J61126-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0021	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0757

Client Sample ID:	P-43 Girls Bathroom Sink 1st Floor	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:11
Lab Sample ID:	J61126-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0065	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0757

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Client Sample ID: P-44 Drinking Fountain by Room 109	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:12
Lab Sample ID: J61126-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0067	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0759

Client Sample ID: P-45 Room 109 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:14
Lab Sample ID: J61126-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0038	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0800

Client Sample ID: P-46 Room 111 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:15
Lab Sample ID: J61126-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0050	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0801

Client Sample ID: P-47 Room 111A Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:17
Lab Sample ID: J61126-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0060	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0801



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611126

Client Sample ID: P-48 Room 108 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:18
Lab Sample ID: J611126-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0059	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0802

Client Sample ID: P-49 Room 108 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:18
Lab Sample ID: J611126-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0061	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0803

Client Sample ID: P-50 Drinking Fountain by Room 108	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:21
Lab Sample ID: J611126-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0024	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0803

Client Sample ID: P-51 Room 130 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:23
Lab Sample ID: J611126-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0804



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J61126

Client Sample ID: P-52 Room 130 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:23
Lab Sample ID: J61126-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0025	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0805

Client Sample ID: P-53 Room 130 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:23
Lab Sample ID: J61126-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0017	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0805

Client Sample ID: P-54 Room 132 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:28
Lab Sample ID: J61126-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0023	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0807

Client Sample ID: P-55 Room 132 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:28
Lab Sample ID: J61126-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0808



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Client Sample ID: P-56 Room 132 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:29
Lab Sample ID: J61126-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0809

Client Sample ID: P-57 Room 111B Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:32
Lab Sample ID: J61126-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0026	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0809

Client Sample ID: P-58 Room 111F Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:34
Lab Sample ID: J61126-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.019	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0810

Client Sample ID: P-59 Rroom 111D Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:35
Lab Sample ID: J61126-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0811



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-60 Room 120 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:38
Lab Sample ID: J6I1126-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0811

Client Sample ID: P-61 Room 120 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:38
Lab Sample ID: J6I1126-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0029	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0812

Client Sample ID: P-62 Room 120 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:38
Lab Sample ID: J6I1126-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0022	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0813

Client Sample ID: P-63 Room 121 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:41
Lab Sample ID: J6I1126-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0813



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID:	P-64 Room 121 Drinking Fountain	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:41
Lab Sample ID:	J6I1126-25		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0023	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0815

Client Sample ID:	P-65 Room 121 Bathroom Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:41
Lab Sample ID:	J6I1126-26		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0028	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0816

Client Sample ID:	P-66 Room 15 Sink	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:43
Lab Sample ID:	J6I1126-27		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0030	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0817

Client Sample ID:	P-67 Room 115 Drinking Fountain	Collected By:	KB-Client
Sample Matrix:	Drinking Water	Collection Date:	09/22/2016 6:47
Lab Sample ID:	J6I1126-28		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0027	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0817



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61126

Client Sample ID: P-68 Room 115 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:42
Lab Sample ID: J61126-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0040	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0818

Client Sample ID: P-69 Room 117 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:50
Lab Sample ID: J61126-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.018	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0819

Client Sample ID: P-70 Room 117 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:50
Lab Sample ID: J61126-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.010	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0819

Client Sample ID: P-71 Room 119 Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:53
Lab Sample ID: J61126-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0035	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0820



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I1126

Client Sample ID: P-72 Room 119 Drinking Fountain	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:53
Lab Sample ID: J6I1126-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0048	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0821

Client Sample ID: P-73 Room 119 Bathroom Sink	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:53
Lab Sample ID: J6I1126-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0073	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0821

Client Sample ID: P-74 Boys Bathroom 1st Floor	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:59
Lab Sample ID: J6I1126-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0061	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0824

Client Sample ID: P-75 Drinking Fountain by Room 119	Collected By: KB-Client
Sample Matrix: Drinking Water	Collection Date: 09/22/2016 6:59
Lab Sample ID: J6I1126-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0034	0.015	0.0010	mg/L		10/07/16 0756	10/14/16 0824

Laboratory
NY: Microbac Laboratories, Inc., New York Division

Definitions
AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611126

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

Microbac Laboratories, Inc. - Chicagoland

NY Lab ID No: 12006

PA DEP ID: 68-04863

New York State Department of Health

New York State Department of Health

Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Michael Fifield
Division Manager
michael.fifield@microbac.com
10/26/2016 22:20

3021 Buck Drive
 Cortland NY 13045
 Phone: (607)763-3408 Fax: (607)763-3416
 NY #10705, EPA #NY00088

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information		Billing Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD	Invoice #:		Job:	YES NO	Accepted?	YES NO
Address:	Parker Elm	Project:		Cooler:	YES NO	Container Material	
Contact:	Bob Martin	Quote ID:		Sample Temp:	12/17	Container Size (in ml)	
Phone:		PO#:		Cooler Seat:	YES NO	Preservative	
Project:	Parker Elm	Rush TAT Est. Days:	2-6 6-7 7-10	Pickup:	YES NO	Commercial/Field Data	
Release to DOH:	Yes	Date Req.:		Dropoff:	C W		
Email Results:	Yes						
Fax Results:	Yes						
Email Results: Rmartin@cortlandschools.org Fax Results: Kwaldby@cortlandschools.org							
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type		
1 P-40 Men's office	9/22/14	6:00AM	KD	DW			
2 -41 Men's office		6:00AM	KD				
3 -42 Men's office		6:00AM	KD				
4 -43 Girls Bathroom		6:11AM	KD				
5 -44 Drinking fountain by Room 107		6:14AM	KD				
6 -45 Room 109 Sink		6:14AM	KD				
7 -46 Room 111 Sink		6:15AM	KD				
8 -47 Room 111A Sink		6:17AM	KD				
Print Name and Company				Signature		Date/Time	
Sampled: Bob Martin Cortland City Schools				<i>[Signature]</i>		9/22/14 1:07	
Received: Bob Martin ECSD				<i>[Signature]</i>		9/22/14 1:07	
Received: Eric D'Amico Microbac				<i>[Signature]</i>		9/22/14 1:31	
Received:							
Received:							
Received:							



J611126

3021 Block Drive
 Cortland NY 13045
 Phone: (607) 763-3403 Fax: (607) 763-3416
 NY #10786, EPA #NY00936

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MINY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)																																			
Name: Cortland ECSD		Address: Parker Elem		Contact:		Phone:		Project:		Quote ID:		PO#: _____		Ice: YES NO		Cooler: YES NO		Sample Temp:		Cooler Seal: YES NO		Pickup: YES NO		Dropoff: C W		Accepted? YES NO		Container Material		Container Size (in Ml)		Preservative		Comment/Field Data													
Rush TAT Bus. Days: < 2-5 6-7 7-10				Date Req: _____				Release to DOH: <input checked="" type="checkbox"/>				Email Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>							
E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>			
E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>				E-mail Results: <input checked="" type="checkbox"/>				Fax Results: <input checked="" type="checkbox"/>			
Sample Information				Matrix				Type				Number of Containers for Analysis Requested				Comments																															
Description/Location		Date		Time		Initial		Matrix		Type		Number of Containers for Analysis Requested		Comments																																	
1 P- 48 Room 108 Sink		6/22/14		6:00A		KCB		DW		1		Leak																																			
2 - 49 Room 108 Bottom Sink		6/23/14		6:15A		KCB		DW		1																																					
3 - 50 Dirty Entry Pyrom 108		6/23/14		6:21A		KCB		DW		1																																					
4 - 51 Room 130 Sink		6/23/14		6:23A		KCB		DW		1																																					
5 - 52 Room 130 Dirty Entry		6/23/14		6:23A		KCB		DW		1																																					
6 - 53 Room 110 Bottom Sink		6/23/14		6:23A		KCB		DW		1																																					
7 - 54 Room 132 Sink		6/23/14		6:23A		KCB		DW		1																																					
8 V - 55 Room 132 Dirty Entry		6/23/14		6:23A		KCB		DW		1																																					
Print Name and Company				Signature				Date/Time				Comments																																			
Sampled: Kati Dwyer Cortland City Sch				[Signature]				6/22/14 7:55A																																							
Received: BOB MARTIN CFS&SO				[Signature]				7/23/14 1:05																																							
Received: Edic Mousen Microbac				[Signature]				9/23/14 12:11																																							
Received:																																															
Received:																																															
Received:																																															

3021 Buick Drive
 Carlisle NY 13045
 Phone: (607) 763-3408 Fax: (607) 763-3415
 NY #10796, EPA NY100056

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Carlisle ECSD	Initial:		Ice:	YES NO	Container Material:	YES NO
Address:	Parker Elem	Time:		Cooler:	YES NO	Container Size (in lbf)	YES NO
Contact:		Date:		Sample Temp:		Preservative:	
Phone:		PO#:		Cooler Seat:	YES NO	Accepted?	YES NO
Project:		Rush TAT Bus. Days:	<2 2-6 6-7 7-10	Pickup:	YES NO	Container Material:	
Quote ID:		Release to DOH: <input checked="" type="checkbox"/>		Dropoff:	C W	Container Size (in lbf)	
Email Results: <input checked="" type="checkbox"/> Rmartin@cartlandschools.org		Date Req:		Accepted?		YES NO	
Fax Results: <input checked="" type="checkbox"/> Kwaldby@cartlandschools.org				Container Material:			
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	Comments
1 P-56 Room 132 Nathan S.K	9/22/14	6:20A	KD	DW			
2 -57 Room 111B Sink		6:32A	KD				
3 -58 Room 111F Sink		6:34A	KD				
4 -59 Room 111D Sink		6:35A	KD				
5 -60 Room 120 Sink		6:38A	KD				
6 -61 Drinking Water		6:39A	KD				
7 -62 Nathan S.K		6:39A	KD				
8 -63 Sink		6:41A	KD				
Print Name and Company				Signature		Date/Time	
Sampled: Keith Dwyer Carlisle City Schs				<i>[Signature]</i>		9/22/14 7:42A	
Received: Bob Martin CBSG				<i>[Signature]</i>		9/22/14 1:05P	
Received: Eric Mouser Microbac				<i>[Signature]</i>		9/22/14 1:51P	
Received:							
Received:							
Received:							

3021 Buck Drive
 Cortland NY 13046
 Phone: (607)763-3403 Fax: (607)763-3446
 NY #10705, EPA #NY000896

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)		
Name:	Cortland ECSD		Bill to:			Ice:	YES	NO	Container Material	YES	NO
Address:	Parker Elem		Address:			Cooler:	YES	NO	(Container Size in Ml)	YES	NO
Contact:			Project:			Sample Temp:			Preservative		
Phone:			Quote ID:			Cooler Sent:	YES	NO	Commercial/Field Data		
Project:			Rush TAT Bus. Days:	<2	2-5	6-7	7-10	Date Req:	Pickup:	YES	NO
PO#:			Roller to DOH: <input checked="" type="checkbox"/> Yes			Dropoff:	C	W	Accepted?	YES	NO
Email Results: <input checked="" type="checkbox"/> Yes <i>Rmartin@ Cortlandschools.org</i> Fax Results: <input checked="" type="checkbox"/> Yes <i>Kwaldby@ Cortlandschools.org</i>			Sample Information			Number of Containers for Analysis Requested			Comments		
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested			Comments		
1 P-64 Park Park	9/22/16	6:41A	KD	DW	DW	1					
2 -65 Park Park		6:41A	KD								
3 -64 Park Park		6:41A	KD								
4 -67 Park Park		6:47A	KD								
5 -68 Park Park		6:47A	KD								
6 -69 Park Park		6:47A	KD								
7 -70 Park Park		6:50A	KD								
8 -71 Park Park		6:50A	KD								

Signature: *[Signature]*
 Date/Time: 9/22/16 7:05 AM
 Received: Bob Martin 9/22/16 1:05
 Received: Eric Mousen Microbac 9/22/16 1:34
 Received:
 Received:

3021 Buck Drive
 Cortland NY 13046
 Phone: (607)768-3403 Fax: (607)768-3416
 NY #10795, EPA #NY000856

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

Client Information
 Name: Cortland ECSD
 Address: Parker Elm
 Contact: _____
 Phone: _____
 Project: _____
 Quote ID: _____
 Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req.: _____
 Release to DOH: Yes
 Email Results: Yes
 Fax Results: Yes
 Billing/Invoice: _____
 MNY Workorder #: _____

Sample Information

Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	Analysis Requested	Receiving Info (Lab Use Only)
1 P-72 Room 119 Pinky Center	9/22/14	6:57A	KG	DW	DW	1		Ice: YES NO Cooler: YES NO Sample Temp: _____ Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material _____ Container Size (in ml) _____ Preservative _____
2 -73 Room 115 Bottom Sink		6:57A	KG					
3 -71 Boys Room 1st Floor		6:57A	KG					
4 -75 Pinky Center by room 119		6:57A	KG					
5 -74								
6 -74								
7 -74								
8								

Comments: _____

Signature and Date/Time:

Print Name and Company	Signature	Date/Time
Sampled: Ken Deegan Cortland City Schools	<i>[Signature]</i>	9/24/14
Received: Bob Manning ECSD	<i>[Signature]</i>	9/24/14
Received: Eric Hanson Microbac	<i>[Signature]</i>	9/24/14
Received:		
Received:		
Received:		



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0619

Cortland City School District

Project Name: Parker School Lead Samples

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 12/08/2016 11:05
Reported: 12/30/2016 16:12

Analytical Testing Parameters

Client Sample ID: P-59 111 D Sink
Lab Sample ID: J6L0619-01
Sample Type: Grab

Collected By: KB-Client
Collection Date: 12/06/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0037, 0.001, mg/L, 12/14/16 1344, 12/23/16 1931

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Item, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. Dayville (NY 11549) NY Lab ID No: 11549 New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L0619

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
12/30/2016 16:12

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

31
 Phone: (607) 763-3403 Fax: (607) 763-3415
 NY #10795, EPA #NY00936

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: CECSD								Ice: YES NO				Cooler: YES NO			
Address: PAIKER								Sample Temp: _____				Cooler Seal: YES NO			
Contact:								Pickup: YES NO				Dropoff: C W			
Phone:								Accepted? YES NO				Container Material			
Project:								Container Size (in Mil)				Preservative			
Quote ID:								Comments/Field Data							
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Date Req.:											
Release to DOH: CEC															
Email Results: Yes RMARTIN@CANTONCITYSCHOOLS.ORG															
Fax Results: Yes KWADYSC@CANTONCITYSCHOOLS.ORG															
Sample Information								Number of Containers for Analysis Requested							
Description/Location		Date	Time	Initial	Matrix	Type									
1 P-59 11D sink		12/6/14	6:20 AM	KB	SW	SW	1								
2															
3															
4															
5															
6															
7															
8															



J6L0619

Comments

Date/Time

Signature

Print Name and Company

Sampled: **Kath Bergon Canton City Schools** *[Signature]*
 Received: **BOB MARTIN S.F. 353** *[Signature]* 12/6/14 6:20 AM
 Received: **Raymond Dawson** *[Signature]* 12/4/14 6:20 AM
 Received: *[Signature]* 12/8/14 11:05 AM
 Received: _____
 Received: _____



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A1390

Cortland City School District

Project Name: Lead Analysis-Parker School

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 01/27/2017 10:40
Reported: 02/13/2017 10:36

Analytical Testing Parameters

Client Sample ID: P-58 Room 111F Bathroom Sink
Lab Sample ID: J7A1390-01
Sample Type: Grab

Collected By: KB-Client
Collection Date: 01/26/17
Collection Time: 06:15

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0175, 0.0150, 0.000500, mg/L, G, 01/27/17 1317, 02/08/17 1632, NY. Method: EPA 200.8, Rv 5.4. Method Notes: X

Analytical Testing Parameters

Client Sample ID: P-63 Room 121 Classroom Sink
Lab Sample ID: J7A1390-02
Sample Type: Grab

Collected By: KB-Client
Collection Date: 01/26/17
Collection Time: 06:20

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00294, 0.0150, 0.000500, mg/L, 01/27/17 1317, 02/08/17 1632, NY. Method: EPA 200.8, Rv 5.4

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
RL: Reporting Limit
X: Exceeds regulatory limit.
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Containers Intact, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A1390

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "Andrew Canale", written over a light gray rectangular background.

Andrew Canale
Project Manager
02/13/2017 10:36

Go Green: Contact Andrew Canale to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7B0783

Cortland City School District

Project Name: Parker Elementary

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 02/10/2017
Reported: 02/16/2017

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (P-69 Room 117 Sink, Drinking Water, J7B0783-01, etc.)

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0174, 0.015 AL, 0.000500, mg/L, 02/13/17 1155, 02/15/17 0911, NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Andrew Canale
Project Manager
andrew.canale@microbac.com
02/16/2017 16:59

3021 Buck Drive
 Cortland NY 13046
 Phone:(607)763-3403 Fax:(607)769-3415
 NY #10795, EPA #NY000836

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Cortland ECSD			Ice:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	Sample Temp:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	Parker Etern			Cooler:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>
Contact:				Pickup:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	Dropoff:	C W
Phone:				Accepted:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	Container Material:	
Project:				Container Size (mL)		Preservative:	
Quote ID:				Number of Containers for Analysis Requested		Comments	
Rush TAT Bus. Days: <2	2-5	5-7	7-10	Date Req:			
Release to DOH: <input checked="" type="checkbox"/> Yes							
Email Results: <input checked="" type="checkbox"/> Yes	R.martin@cortlandschools.org						
Fax Results: <input checked="" type="checkbox"/> Yes	K.walby@cortlandschools.org						
Sample Information				Matrix			
Description/Location	Date	Time	Initial	Type			
1 P-69 Room 111 Sink	2/10/11	7:30 AM	KS	DW	1		
2							
3							
4							
5							
6							
7							
8							
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Keith Berggren Cortland City Schools		<i>Keith Berggren</i>		2/10/11 7:30 AM			
Received: BOB MARTIN C-15050		<i>Bob Martin</i>		2/14/17 12:57			
Received: Brenna Murray		<i>Brenna Murray</i>		2/10/17 1339			
Received:							
Received:							



Cortland City School District



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0234

Cortland City School District

Project Name: Lead Analysis

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 03/01/2017 10:50
Reported: 03/08/2017 17:13

Analytical Testing Parameters

Client Sample ID: P-58 Room 111F Bathroom Sink
Lab Sample ID: J7C0234-01
Sample Type: Grab

Collected By: RB-Client
Collection Date: 02/28/17
Collection Time: 06:00

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0198, 0.0150, 0.000500, mg/L, G, 03/02/17 1407, 03/03/17 1446, NY.

Analytical Testing Parameters

Client Sample ID: P-69 Room 117 Sink
Lab Sample ID: J7C0234-02
Sample Type: Grab

Collected By: RB-Client
Collection Date: 02/28/17
Collection Time: 06:02

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0104, 0.0150, 0.000500, mg/L, 03/02/17 1407, 03/03/17 1446, NY.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Description, Yes/No, Description, Yes/No. Rows: Custody Seals Intact and/or No Evidence of Tampering (Yes, Containers Intact, Yes); COC/Labels Agree (Yes, Preservation Correct (or not required), Yes); Received on Ice (or not required) (Yes).

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7C0234

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "Andrew Canale", written over a light gray rectangular background.

Andrew Canale
Project Manager
03/08/2017 17:13

Go Green: Contact Andrew Canale to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

MNY Workorder #

J7C0234



Client Information				Billing/Invoice:			
Name: PARKER SEWELL				Analysis Requested			
Address: MADISON ST				Ice: YES NO			
Contact: CRSD				Cooler: YES NO			
Project:				Sample Temp:			
Quote ID:				Cooler Seal: YES NO			
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Pickup: YES NO			
Release to DOH: Yes				Dropoff: C W			
Email Results: Yes				Accepted? YES NO			
Fax Results: Yes				Container Material			
Email: Rmartin@corlundschoos.org/Knowledge@				Container Size(in Ml)			
PO#:				Preservative			
Date Req.:				Comments/Field Data			
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 P-58 Room 117 Bottom Sink	2/25/17	6:30AM	NR	DW Grab	1		
2 P-69 Room 117 Sink	2/25/17	6:30AM	NR				
3							
4							
5							
6							
7							
8							

Print Name and Company	Signature	Date/Time	Comments
Sampled: Kelly Byron PARKER	<i>[Signature]</i>	2/25/17 6:30AM	
Received: BOB MORRISON CRSD	<i>[Signature]</i>	2/25/17 10:50	
Received: ALOYNA DAWSON	<i>[Signature]</i>	2/21/17 10:50	
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.