



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J2227

Cortland City School District

Project Name: Lead Analysis

Bob Martin
 1 Valley View Drive
 Cortland, NY 13045

Project / PO Number: N/A
 Received: 10/28/2020
 Reported: 11/18/2020

Analytical Testing Parameters

Client Sample ID:	S-1 Bathroom Sink rm 20	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 5:36
Lab Sample ID:	J0J2227-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1258	LLW

Client Sample ID:	S-2 Classroom Sink rm 20	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 5:36
Lab Sample ID:	J0J2227-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0110	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1303	LLW

Client Sample ID:	S-4 Bathroom Sink rm 30	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 5:40
Lab Sample ID:	J0J2227-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1305	LLW

Client Sample ID:	S-5 Classroom Sink rm 30	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 5:40
Lab Sample ID:	J0J2227-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1307	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-7 Bathroom Sink rm 40	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:43
Lab Sample ID: J0J2227-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0146	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1309	LLW

Client Sample ID: S-8 Classroom Sink rm 40	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:43
Lab Sample ID: J0J2227-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.015 AL	0.0020	mg/L	D	11/09/20 1057	11/10/20 1307	LLW

Client Sample ID: S-10 Bathroom Sink rm 50	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:54
Lab Sample ID: J0J2227-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0121	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1316	LLW

Client Sample ID: S-11 Classroomn Sink rm 50	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:45
Lab Sample ID: J0J2227-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0165	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1318	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-13 Bathroom Sink rm 60	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:48
Lab Sample ID: J0J2227-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0335	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1320	LLW

Client Sample ID: S-14 Classroom Sink rm 60	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:48
Lab Sample ID: J0J2227-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1322	LLW

Client Sample ID: S-16 Bathroom Sink rm 90	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:50
Lab Sample ID: J0J2227-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0071	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1323	LLW

Client Sample ID: S-17 Classroom Sink rm 90	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:50
Lab Sample ID: J0J2227-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1327	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-19 Bathroom Sink rm 100	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:53
Lab Sample ID: J0J2227-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0259	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1329	LLW

Client Sample ID: S-20 Classroom Sink rm 100	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:53
Lab Sample ID: J0J2227-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1331	LLW

Client Sample ID: S-22 Bathroom Sink rm 110	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:55
Lab Sample ID: J0J2227-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1333	LLW

Client Sample ID: S-23 Classroom Sink rm 110	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:55
Lab Sample ID: J0J2227-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0082	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1338	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-25 Bathroom Sink rm 120	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:57
Lab Sample ID: J0J2227-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1340	LLW

Client Sample ID: S-26 Classroom Sink rm 120	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:57
Lab Sample ID: J0J2227-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1342	LLW

Client Sample ID: S-28 Bathroom Sink rm 130	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:59
Lab Sample ID: J0J2227-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0182	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1344	LLW

Client Sample ID: S-29 Classroom Sink 1 rm 130	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 5:59
Lab Sample ID: J0J2227-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		11/09/20 1057	11/09/20 1345	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-30 Classroom Sink 2 rm 130	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:01
Lab Sample ID: J0J2227-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0135	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1355	LLW

Client Sample ID: S-32 Bathroom Sink rm 150	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:05
Lab Sample ID: J0J2227-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0105	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1400	LLW

Client Sample ID: S-33 Classroom Sink rm 150	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:06
Lab Sample ID: J0J2227-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1402	LLW

Client Sample ID: S-35 Bathroom sink rm 160	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:07
Lab Sample ID: J0J2227-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1404	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-36 Classroom Sink rm 160	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:07
Lab Sample ID: J0J2227-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1406	LLW

Client Sample ID: S-38 Bathroom Sink rm 170	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:09
Lab Sample ID: J0J2227-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0167	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1407	LLW

Client Sample ID: S-39 Classroom Sink rm 170	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:09
Lab Sample ID: J0J2227-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1413	LLW

Client Sample ID: S-41 Bathroom Sink rm 180	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:11
Lab Sample ID: J0J2227-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0090	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1415	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-42 Classroom Sink rm 180	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:11
Lab Sample ID: J0J2227-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1417	LLW

Client Sample ID: S-44 Bathroom Sink rm 190	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:12
Lab Sample ID: J0J2227-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0144	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1418	LLW

Client Sample ID: S-45 Classroom Sink 1 rm 190	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:13
Lab Sample ID: J0J2227-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0074	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1420	LLW

Client Sample ID: S-46 Classroom Sink 2 Rm 190	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:13
Lab Sample ID: J0J2227-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1424	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-48 Bathroom Sink rm 200	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:15
Lab Sample ID: J0J2227-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1426	LLW

Client Sample ID: S-49 Classroom Sink rm 200	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:15
Lab Sample ID: J0J2227-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1428	LLW

Client Sample ID: S-52 Sink Rm 222	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:15
Lab Sample ID: J0J2227-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0700	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1429	LLW

Client Sample ID: S-54 Girl Lockerroom Office Sink	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:20
Lab Sample ID: J0J2227-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0086	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1435	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-55 Girls Lockerroom Sink 1	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:21
Lab Sample ID: J0J2227-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0363	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1437	LLW

Client Sample ID: S-56 Girls Lockerroom Sink 2	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:21
Lab Sample ID: J0J2227-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0175	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1439	LLW

Client Sample ID: S-57 Boys Lockerroom Sink	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:24
Lab Sample ID: J0J2227-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0455	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1440	LLW

Client Sample ID: S-58 Classroom Sink 1 rm 270	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:27
Lab Sample ID: J0J2227-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0080	0.015 AL	0.0010	mg/L		11/09/20 1059	11/09/20 1442	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-59 Classroom Sink 2 rm 270	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:28
Lab Sample ID: J0J2227-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0261	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1455	LLW

Client Sample ID: S-61 Daycare Sink rm 195	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:29
Lab Sample ID: J0J2227-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0082	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1501	LLW

Client Sample ID: S-62 Hand Wash Sink rm 300	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:17
Lab Sample ID: J0J2227-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0172	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1502	LLW

Client Sample ID: S-63 Kitchen Slnk Left	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:31
Lab Sample ID: J0J2227-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0480	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1504	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-64 Kitchen Sink Right	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:31
Lab Sample ID: J0J2227-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0164	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1506	LLW

Client Sample ID: S-67 Classroom Sink rm 360	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:39
Lab Sample ID: J0J2227-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0142	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1508	LLW

Client Sample ID: S-70 Classroom Sink rm 380	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:40
Lab Sample ID: J0J2227-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1514	LLW

Client Sample ID: S-71 Bathroom Sink rm 400a	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:44
Lab Sample ID: J0J2227-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0531	0.015 AL	0.0051	mg/L	D	11/09/20 1100	11/10/20 1313	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-72 Bathroom Sink rm 402	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:46
Lab Sample ID: J0J2227-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1517	LLW

Client Sample ID: S-73 Bathroom Sink rm 403	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:47
Lab Sample ID: J0J2227-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0138	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1519	LLW

Client Sample ID: S-74 Bathroom Sink rm 502	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:03
Lab Sample ID: J0J2227-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1521	LLW

Client Sample ID: S-75 Classroom Sink rm 502	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:03
Lab Sample ID: J0J2227-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1524	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-77 Bathroom Sink rm 503	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:59
Lab Sample ID: J0J2227-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0071	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1526	LLW

Client Sample ID: S-78 Classroom Sink rm 503	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:59
Lab Sample ID: J0J2227-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1528	LLW

Client Sample ID: S-80 Bathroom Sink rm 504	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:51
Lab Sample ID: J0J2227-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1530	LLW

Client Sample ID: S-81 Classroom Sink rm 504	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:51
Lab Sample ID: J0J2227-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1536	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-83 Bathroom Sink rm 70B	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:52
Lab Sample ID: J0J2227-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1537	LLW

Client Sample ID: S-84 Classroom Sink rm 508	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:54
Lab Sample ID: J0J2227-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1539	LLW

Client Sample ID: S-85 Bathroom Sink rm 509	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:56
Lab Sample ID: J0J2227-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1541	LLW

Client Sample ID: S-86 Classroom Sink rm 509	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:56
Lab Sample ID: J0J2227-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		11/09/20 1100	11/09/20 1543	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-89 Classroom Sink rm 510	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:01
Lab Sample ID: J0J2227-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1909	LLW

Client Sample ID: S-91 Bathroom Sink rm 511	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:05
Lab Sample ID: J0J2227-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1915	LLW

Client Sample ID: S-92 Classroom Sink rm 511	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:05
Lab Sample ID: J0J2227-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1917	LLW

Client Sample ID: S-94 Bathroom Sink rm 70	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:08
Lab Sample ID: J0J2227-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1919	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID: S-95 Classroom Sink rm 70	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:08
Lab Sample ID: J0J2227-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1921	LLW

Client Sample ID: S-97 Bathroom Sink rm 80	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:09
Lab Sample ID: J0J2227-67	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0085	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1926	LLW

Client Sample ID: S-98 Classroom Sink rm 80	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:09
Lab Sample ID: J0J2227-68	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1928	LLW

Client Sample ID: S-100B Bottle Fill Stat by 402	Collected By: NH-Client
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:12
Lab Sample ID: J0J2227-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1930	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2227

Client Sample ID:	S-101 AUD. Hand Wash	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 6:30
Lab Sample ID:	J0J2227-70		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1932	LLW

Client Sample ID:	S-102 Kitchen Prerinse	Collected By:	NH-Client
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 7:20
Lab Sample ID:	J0J2227-71		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0078	0.015 AL	0.0010	mg/L		11/09/20 1244	11/09/20 1934	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:


Sara Lechleitner
Customer Relationship Coordinator
Reported: 11/18/2020 11:56

CHAIN OF CUSTODY RECORD
Number
Instructions on back

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Lab Report Address Invoice Address
 Client Name: Cortland City School District Smith Client Name: Cortland City School District
 Address: 33 Wheeler Ave Address: 1 Valley View Drive
 City, State, Zip: Cortland, NY 13045 City, State, Zip: Cortland, NY 13045
 Contact: Neal Helms Contact: Neal Helms
 Telephone No.: (607) 345-4147 Telephone No.: (607) 345-4147
 Send Report Via: Mail Fax e-mail (address) *whelp@CortlandSchools.org* Send Invoice via: Mail Fax e-mail (address)
 Project: Lead Location: Smith School PO No.:
 Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 Report Type (needed by)
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address)
 Compliance Monitoring? Yes No
 Agency/Program DOH Lead

Sampler Signature: *Neal Helms* Sampler Phone No.: (607) 345-4147
 * Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No of Containers	Matrix	Grab / Comp	Preservative Types **	Lead	Additional Note
	S-1 Bathroom Sink rm 20	10/28/20	05:36	1	DW	gr	1	1	First Draw
	S-2 Classroom Sink rm 20	10/28/20	05:36	1	DW	gr	1	1	""
	S-4 Bathroom Sink rm 30	10/28/20	05:40	1	DW	gr	1	1	""
	S-5 Classroom Sink rm 30	10/28/20	05:40	1	DW	gr	1	1	""
	S-7 Bathroom Sink rm 40	10/28/20	05:43	1	DW	gr	1	1	""
	S-8 Classroom sink rm 40	10/28/20	05:43	1	DW	gr	1	1	""
	S-10 Bathroom Sink rm 50	10/28/20	05:54	1	DW	gr	1	1	""
	S-11 Classroom Sink rm 50	10/28/20	05:45	1	DW	gr	1	1	""
	S-13 Bathroom Sink rm 60	10/28/20	05:48	1	DW	gr	1	1	""
	S-14 Classroom Sink rm 60	10/28/20	05:48	1	DW	gr	1	1	""

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Dispose as appropriate Return Archive

Relinquished By (signature) *Neal Helms* Date/Time *10/28/20 10:10*
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number *Instructions on back*

TO BE COMPLETED BY MICROBAC

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Invoice Address
 Client Name: Cortland City School District
 Address: 1 Valley View Drive
 City, State, Zip: Cortland, NY 13045

Lab Report Address
 Client Name: Cortland City School District, Smith Elem
 Address: 33 Wheeler Ave
 City, State, Zip: Cortland, NY 13045

Temperature Upon Receipt (°C)
 Therm ID
 Holding Time
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Contact: Neal Helms
 Telephone No.: (604) 345-4147

Contact: Neal Helms
 Telephone No.: (607) 345-4147

Compliance Monitoring? Yes No
 Agency/Program

Send Report via: Mail Fax e-mail (address)
 Location: Smith School

Send Invoice via: Mail Fax e-mail (address)
 PO No.:

Sampler Signature: Neal Helms

Sampler Phone No.: (607) 345-4147

Sampled by (PRINT): Neal Helms

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grav / Comp	Preservative Types **	Lead	Additional Notes
	S-16 Bathroom Sink rm 90	10/28/20	05:50	1	DW	gr	1	1	First Draw
	S-17 Classroom sink rm 90	10/28/20	05:50	1	DW	gr	1	1	""
	S-19 Bathroom Sink rm 100	10/28/20	05:53	1	DW	gr	1	1	""
	S-20 Classroom Sink rm 100	10/28/20	05:53	1	DW	gr	1	1	""
	S-22 Bathroom Sink rm 110	10/28/20	05:55	1	DW	gr	1	1	""
	S-23 Classroom Sink rm 110	10/28/20	05:55	1	DW	gr	1	1	""
	S-25 Bathroom Sink rm 120	10/28/20	05:57	1	DW	gr	1	1	""
	S-26 Classroom Sink rm 120	10/28/20	05:57	1	DW	gr	1	1	""
	S-28 Bathroom Sink rm 130	10/28/20	05:59	1	DW	gr	1	1	""
	S-29 Classroom Sink 1 rm 130	10/28/10	05:59	1	DW	gr	1	1	""

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
<i>Neal Helms</i>	10/28/20	<i>Neal Helms</i>	10/10
<i>Neal Helms</i>			
<i>Neal Helms</i>			

CHAIN OF CUSTODY RECORD

Number *Instructions on back* **TO BE COMPLETED BY MICROBAC**

Lab Report Address Invoice Address Turnaround Time
 Client Name: Cortland City School District Smith Client Name: Cortland City School District
 Address: 33 Wheeler Ave Address: 1 Valley View Drive
 City, State, Zip: Cortland, NY 13045 City, State, Zip: Cortland, NY 13045
 Contact: Neal Helms Contact: Neal Helms
 Telephone No.: (607) 345-4147 Telephone No.: (607) 345-4147
 Send Report via: Mail Fax e-mail (address) e-mail (address) Send Invoice Via: Mail Fax e-mail (address)
 Project: Lead Location: Smith School PO No.:
 Compliance Monitoring? Yes No
 Agency/Program DOH Lead

Report Type: (needed by)
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A
 Holding Time
 Temperature Upon Receipt (°C)
 Therm ID
 Sampler Signature: *Neal Helms* Sampler Phone No.: (607) 345-4147
 * Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Lead	Additional Notes
S-30	Classroom Sink 2 rm 130	10/28/20	06:01	1	DW	gr	1	1	First Draw
S-32	Bathroom Sink rm 150	10/28/20	06:05	1	DW	gr	1	1	""
S-33	Classroom Sink rm 150	10/28/20	06:06	1	DW	gr	1	1	""
S-35	Bathroom sink rm 160	10/28/20	06:07	1	DW	gr	1	1	""
S-36	Classroom Sink rm 160	10/28/20	06:07	1	DW	gr	1	1	""
S-38	Bathroom Sink rm 170	10/28/20	06:09	1	DW	gr	1	1	""
S-39	Classroom Sink rm 170	10/28/20	06:09	1	DW	gr	1	1	""
S-41	Bathroom Sink rm 180	10/28/20	06:11	1	DW	gr	1	1	""
S-42	Classroom Sink rm 180	10/28/20	06:11	1	DW	gr	1	1	""
S-44	Bathroom Sink rm 190	10/28/20	06:12	1	DW	gr	1	1	""

Requested Analysis
 Sample Disposition: Dispose as appropriate Return Archive
 Relinquished By (signature) *Neal Helms* Date/Time *10/10*
 Relinquished By (signature) *Neal Helms* Date/Time *10/10*
 Relinquished By (signature) *Neal Helms* Date/Time *10/10*

CHAIN OF CUSTODY RECORD

Number *Instructions on back*

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)
Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 2 Level 3 Level 4 EDD

Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Compliance Monitoring? Yes No
 Agency/Program DOH Lead

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Invoice Address
Client Name: Cortland City School District
Address: 1 Valley View Drive
City, State, Zip: Cortland, NY 13045
Contact: Neal Helms
Telephone No.: (607) 345-4147

Send Report via: Mail Fax e-mail (address) e-mail (address)
Send Invoice via: Mail Fax e-mail (address)

Lab Report Address
Client Name: Cortland City School District Smith
Address: 33 Wheeler Ave
City, State, Zip: Cortland, NY 13045
Contact: Neal Helms
Telephone No.: (607) 345-4147

Project: Lead
Location: Smith School
PO No.:

Sampled by (PRINT): Neal Helms
Sampler Signature: *Neal Helms*
Sampler Phone No.: (607) 345-4147

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Lead	Additional Notes
	S-45 Classroom Sink 1 rm 190	10/28/20	06:13	1	DW	gr	1	1	""
	S-46 Classroom sink 2 rm 190	10/28/20	06:13	1	DW	gr	1	1	""
	S-48 Bathroom Sink rm 200	10/28/20	06:15	1	DW	gr	1	1	""
	S-49 Classroom Sink rm 200	10/28/20	06:15	1	DW	gr	1	1	""
	S-52 Sink rm 222	10/28/20	07:15	1	DW	gr	1	1	""
	S-54 Girl locker room Office Sink	10/28/20	06:20	1	DW	gr	1	1	""
	S-55 Girls Locker room Sink 1	10/28/20	06:21	1	DW	gr	1	1	""
	S-56 Gils Locker room Sink 2	10/28/20	06:21	1	DW	gr	1	1	""
	S-57 Boys Locker room Sink	10/28/20	06:24	1	DW	gr	1	1	""

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Comments
Relinquished By (signature) *Neal Helms* Date/Time *10/28/20 10:10*
Relinquished By (signature) _____ Date/Time _____
Relinquished By (signature) _____ Date/Time _____

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Lab Report Address

Client Name: Cortland City School District Smith

Address: 33 Wheeler Ave

City, State, Zip: Cortland, NY 13045

Contact: Neal Helms

Telephone No.: (607) 345-4147

Send Report via: Mail Fax e-mail (address)

Project: Lead

Turnaround Time

Routine (5 to 7 business days)
 RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address)

PO No.:

Location: Smith School

Compliance Monitoring? Yes No

Agency/Program DOH Lead

Sampler Phone No.: (607) 345-4147

Sampler Signature: *Neal Helms*

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Lead	Additional Notes
S-58	Classroom Sink 1 rm 270	10/28/20	06:27	1	DW	gr	1	1	First Draw
S-59	Classroom Sink 2 rm 270	10/28/20	06:28	1	DW	gr	1	1	""
S-61	Daycare Sink rm 195	10/28/20	06:29	1	DW	gr	1	1	""
S-62	Hand Wash sink rm 300	10/28/20	07:17	1	DW	gr	1	1	""
S-63	Kitchen Sink Left	10/28/20	06:31	1	DW	gr	1	1	""
S-64	Kitchen Sink Right	10/28/20	06:31	1	DW	gr	1	1	""
S-67	Classroom Sink rm 360	10/28/20	06:39	1	DW	gr	1	1	""
S-70	Classroom Sink rm 380	10/28/20	06:40	1	DW	gr	1	1	""

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
<i>Neal Helms</i>	10/28/20	<i>Neil Per</i>	10/28/20

rev. 7/18/18

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number *Instructions on back*

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Mail Fax e-mail (address)

Send Invoice via: Mail Fax e-mail (address)

Send Invoice to: *Cortland School*

PO No.:

Compliance Monitoring? Yes No

Agency/Program DOH Lead

Sampler Phone No.: (607) 345-4147

Invoice Address

Client Name: Cortland City School District

Address: 1 Valley View Drive

City, State, Zip: Cortland, NY 13045

Contact: Neal Helms

Telephone No.: (607) 345-4147

Location: Smith School

Sampler Signature: *Neal Helms*

Sampler Name: Neal Helms

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (9) Unpreserved

Requested Analysis

Lab Report Address

Client Name: Cortland City School District Smith

Address: 33 Wheeler Ave

City, State, Zip: Cortland, NY 13045

Contact: Neal Helms

Telephone No.: (607) 345-4147

Send Report via: Mail Fax e-mail (address)

Project: Lead

Sampled by (PRINT): Neal Helms

Comments

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) *Neal Helms* Date/Time *10/28/20 10:10*

Relinquished By (signature) *Neal Helms* Date/Time

Relinquished By (signature) *Neal Helms* Date/Time

Received By (signature) Date/Time

Received By (signature) Date/Time

Received By (signature) Date/Time

Additional Notes

First Draw

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

""

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Instructions on back
 TO BE COMPLETED BY MICROBAC
 Temperature Upon Receipt (°C) 18.5
 Therm ID *044*
 Holding Time
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A
 Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
 Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address)
 Compliance Monitoring? Yes No
 Agency/Program DOH Lead
 Invoice Address
 Client Name: Cortland City School District
 Address: 1 Valley View Drive
 City, State, Zip: Cortland, NY 13045
 Contact: Neal Helms
 Telephone No.: (607) 345-4147
 Send Report via: Mail Fax e-mail (address) *whelpsc@earthlink.net* Send Invoice via: Mail Fax e-mail (address)
 Project: Lead PO No.:
 Location: Smith School
 Sampler Signature: *Neal Helms*
 Sampler Phone No.: (607) 345-4147

Sampled by (PRINT): Neal Helms
 * Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Lead	Additional Notes
	S-98 Classroom Sink rm 80	10/28/20	07:09	1	DW	gr	1	1	First Draw
	S-100B Bottle Fill Stat. by 402	10/28/20	07:12	1	DW	gr	1	1	
	S-101 AUD. Hand Wash	10/28/20	06:30	1	DW	gr	1	1	
	S-102 Kitchen Prerinse	10/28/20	07:20	1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	
				1	DW	gr	1	1	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Sample Disposition Dispose as appropriate Return Archive
 Relinquished By (signature) *Neal Helms* Date/Time 10/28/20
 Relinquished By (signature) *Neal Helms* Date/Time 10/28/20
 Relinquished By (signature) *Neal Helms* Date/Time 10/28/20
 Relinquished By (signature) *Neal Helms* Date/Time 10/28/20