



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J8D1378

Cortland City School District

Project Name: Smith Elementary

Bob Martin
1 Valley View Drive
Cortland, NY 13045

Project / PO Number: N/A
Received: 04/25/2018 09:59
Reported: 05/04/2018 14:43

Analytical Testing Parameters

Client Sample ID: S-66 360 Bathroom Sink - Retest
Lab Sample ID: J8D1378-01
Sample Type: Grab

Collected By: NH-Client
Collection Date: 04/25/18
Collection Time: 06:30

Table with columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0186, 0.0150, 0.000500, mg/L, G, 04/27/18 1510, 05/01/18 1508, NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 8.0°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Items include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Christine Pechacek

Christine Pechacek
Operations Manager
05/04/2018 14:43

Go Green: Contact Christine Pechacek to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.



CHAIN OF CUSTODY RECORD

3821 Buck Drive Cortland, NY 13045 607.753.3403
2369 Elmira Street, Suite C Sayre, PA 18840 570.888.0169
1620 North Main Avenue Scranton, PA 18508 570.348.0775
4359 Linglestown Road Harrisburg, PA 17112 717.651.9700

Lab Report Address

Client Name: Smith Elementary
Address: Wheeler Ave
City, State, Zip: Cortland, NY 13045
Contact: Neal Helms
Telephone No.: 607-745-4147

Invoice Address

Client Name: Cortland Schools
Address: Valley View Prvse
City, State, Zip: Cortland NY 13045
Contact: Neal Helms
Telephone No.: 607-745-4147

Turnaround Time

Route (5 to 7 business days)
RUSH* (notify lab)

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 8.0
Therm ID
Holding Time
Samples Received on ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Send Report via:

Mail Fax e-mail (address) Telephone No. 607-745-4147
Project: lead


Compliance Monitoring? Yes No
Agency/Program

Sampled by (PRINT):

Neal Helms
Signature: Neal Helms
Sampler Phone No.: 607-745-4147

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Table with columns: Lab ID, Client Sample ID, Date Collected, Time Collected, No. of Containers, Matrix, Grab/Comp, Preservative Types, Relinquished By (signature), Date/Time, Sample Disposition, Received By (signature), Date/Time. Includes handwritten entries for sample S-66 and signatures of Neal Helms and Dorothy Moskell.



Cortland City School District